

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

E-mail: [gargatul@hotmail.com](mailto:gargatul@hotmail.com), Tel:- 011-26189168

No. F6/DFS/MS/School/2016/ 52/585

Dated: 13/04/16

**FIRE SAFETY CERTIFICATE**

Certified that **S.D.M.C. Primary School (Girls) located at Khizrabad-I (Hindi), New Delhi- 110025** comprised of ground and one upper floor was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2013/126 dated 26/03/2013. The school building was re-inspected by the officer concerned of this department on 29/03/2016 in presence of Mr. Yatindra Shrama, teacher of the school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. F.6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the under mentioned conditions.

Issued on 13/04/16 at New Delhi by.

  
(ATUL GARG)  
Dy. CHIEF FIRE OFFICER

Copy to: -

1. The Principal, S.D.M.C. Primary School (Girls), Khizrabad-I (Hindi), New Delhi-110025.
2. The Commissioner, SDMC, Civic Centre, Minto road, NewDelhi-110002.

**Conditions for the Validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building : S.D.M.C. Primary School (Girls), Khizrabad-I (Hindi), New Delhi- 110025
1. Type of Occupancy : Educational
2. Type of Case : Renewal
3. Details of previous NOC : F6/DFS/MS/School/2013/126 dated 26/03/2013
4. Fire Safety directives letter No : Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011.
5. Date of inspection : 29.03.2016
6. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(M.Rd)
7. Name and designation of officers  
from the building side : Mr. Yatindra Shrama, teacher
9. Year of Construction : 1988
10. Applicant's letter No. : Nil dated 20.01.2016.

S.D.M.C. Primary School (Girls), Khizrabad-I (Hindi), New Delhi- 110025 is comprised of ground and one upper floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Directorate of Education circular	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> </ul>	06 mts	Provided	MR
	<ul style="list-style-type: none"> <li>• Gate width</li> </ul>	4.5 mts	Provided	MR
	<ul style="list-style-type: none"> <li>• Width of internal road</li> </ul>	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	02 Nos.	Provided	MR
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	1.5 mts or less & 0.75 mt	1.50 mts each	MR
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	Provided (01)	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 mts	Provided (1 mts)	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N/A	N/A	N/A



	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	N/A N/A	N/A N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	08 nos. ABC type ISI marked	Provided Provided Provided	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	---- 30 m 5 mm	N/A N/A N/A	N/A N/A N/A
7	<b>Automatic fire detection and alarming system</b> <b>Not required</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A N/A	N/A N/A	N/A N/A
13	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> </ul>	--- N/A N/A N/A N/A N/A	---- N/A N/A N/A N/A N/A	----- N/A N/A N/A N/A N/A



	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		----	-----	-----
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>	<b>Not Applicable</b>		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	01 ABC type fire extinguisher is provided near elect. Panel.	MR

The fire protection systems provided in the building were test checked and found functional at the

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/School/2013/126 dated 26/03/2013, renewal under the Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 is recommended.


DFA is put up for approval & signature please

DO(SZ)

-----  
DCFO(SZ)

5/4/16

5/4/16

  
17/4/2016

Signature of the Inspecting Officer

Name (M.K. CHATTOPADHYAY)

Assistant Divisional Officer (MRD)