

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI – 110001**

No.F6/DFS/MS/GH/2016/ N021587

Dated : 18/4/16

FIRE SAFETY CERTIFICATE

Certified that **Star Plaza Guest House 5158, Main Bazar, Pahar Ganj, New Delhi** comprises of **Basement (LGF), Ground + 03 Upper floor, basement (LGF) storage, Ground floor – reception & office, 1st floor to 3rd floor - 08 guest rooms at each floor total 24 guest rooms** was granted FSC by this department vide letter **No.F6/DFS/MS/GH/2012/3254** dated **07/09/2012**. The premises was re-inspected by the officer concerned of this department on **05/04/2016** in the presence of **Mr Ashish (Manager)** and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential Group A-1 as above 24 guest rooms only** with effect from 18/4/16 2016 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. mentioned below.
Issued on 18/4/16 at New Delhi by.

(Dr. G.C.Misra)
Director

Delhi Fire Service
Ph: - 011-23414333

Copy to:-

1. The Joint. Commissioner of Police (Lic),
First Floor, P.S. Defence Colony New Delhi
2. The Licensee,
Star Plaza Guest House,
5158, Main Bazar, Pahar Ganj, New Delhi .

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to it expiry.

INSPECTION REPORT

1. Name & address of the building:- Star Plaza Guest House 5158, Main Bazar, Pahar Ganj, New Delhi.
2. Type of occupancy:- Residential Group A-1 Basement (Lower Ground Floor), Ground + 3 Upper Floors (Total 24 Guest Rooms)
3. Type of case:- Renewal
4. Details of previous FSC :- No. F6/DFS/MS/GH/2012/3254 dated 07/09/2012.
5. Fire safety directives No.- N/A
6. Date of inspection:- 05/04/16
7. Name of the inspecting officer:- D.O. Gurmukh Singh
8. Name & designation of officer
From the building side:- Sh. Ashish (Manager)
9. Year of construction:- 2009
10. Applicant's letter No:- 819/Joint CP/Lic (H). dated 17/03/16

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	6 mtrs.	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No	01 No.	MR
	2. Basements (LGF)	01 No.	01 No.	MR
	B. Width of staircase			
	1. Upper floors	80 cms	125 cms.	MR
	2. Basements	80 cms.	114 cms.	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 Mtr.	1 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Exhaust fan	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	10 Nos.	MR

h

	2) Types	ABC & CO2	ABC, CO2 &	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 no.	01 no.	MR
	2) Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System /Intercom	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	NA	NA	NA
	2) Number of hydrants per floor	NA	NA	NA
	3) Hose box	NA	NA	NA
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	225 LPM	225 LPM	MR
	b) Head of pump	30 Mtr.	30 Mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	N/A	N/A	N/A

h


-N-15

	capacity			
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 Ltr.	5,000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

Shortcomings issued vide our letter dated 10/09/15 found rectified.

The fire protection system provided in the guest house were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/GH/2012/3254 dated 07/09/2012, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.


Gurmukh Singh
Divisional Officer

Dy CRO (DDZ)