

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/2016/ school/w2/584

Dated: 13/04/2016

FIRE SAFETY CERTIFICATE

Certified that Vikram Public School, L-Block, Prem Nagar-II, Kirari, New Delhi-110086 comprised of Ground + One upper floor only owned/occupied by Vikram Public School has already been issued fire safety certificate vide letter no. F.6/DFS/MS/School/2012/1125 Dt. 28/02/2012. The premises was re-inspected by the officer from this department on dated 12/03/2016 in the presence of Sh. Meena Gahlaut (Manager) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deem complied with the requirements of Circular No 262-362 dated 17/01/2005 issued by Director of Education and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 13/04/2016 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 13/04/16 at New Delhi by


(Dr. G. C Misra)
Director
Ph: 011-23414000

Copy to:

1. The Principal, Vikram Public School, L-Block, Prem Nagar-II, Kirari, New Delhi-110086.
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORTSingle Block.
Gr. + One

1. Name & address of the building : Vikram Public School, L-Block, Prem Nagar-II, Kirari
New Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : Renewal ✓
4. Details of previous NOC : Letter No. F.6/DFS/MS/School/2012/1125 Dt. 28/02/2012
5. Fire Safety directives letter No : Dir of Education. Cir .17/01/2005 ✓
6. Date of inspection : 12/03/2016
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers
from the building side : Sh. Meena Gahlaut (Manager)
9. Year of Construction : 1996
10. Applicant's letter No. : Nil Dated 22/02/2016 _____
Plot area:-600 sq Yards Covered area:-400 + 400 sq Yards No.'s of Student:-210 No.'s of
Classrooms:-10+9 rooms for other purpose

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 mtr	P	MR ✓
	• Gate width	4.5 mtr	P	M/R ✓
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	02	02	MR ✓
	• Basements	—	—	—
	b. Width of staircases			
	• Upper Floors	1.50 mtr each	1.50 mtr each	M/R ✓
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	01	01	MR ✓
	g. Width of Corridor	1.50 mtr	02 mtr	MR ✓
	h. Door Size	1 mtr	1 mtr	M/R ✓

3	Compartmentation.	—	—	—
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	Smoke Management System.			
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	Fire Extinguishers			
	• Total numbers	4 ABC	04	MR
	• Types		ABC	MR
	• IS marking	ISI marked	YES	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	One	P	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	MOEFA	—	—	—
9	Public Address System.	—	—	—
10	Automatic Sprinkler System.			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants			
	• Size of riser/down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—

12	Yard Hydrants.			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements.			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	450 LMP	P	MR
	➤ Head of the pump	40 m	P	MR
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump	—	—	—
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	—	—	—
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	2500 ltr	P	MR
15	Exit Signage.			
		—	—	—
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply			
		—	—	—

18	Refuge Area.			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

Note:-General requirements for school as per Director of Education Circular dated...17/01/2005

1. Escape route..... **Clear**
2. LPG cylinders in laboratories **No**
3. Electric wiring **Conduct**.....MCB**Provided**.....
Electric circuit.....**ELCB provided**.....
4. Electric meter board **Not Below**.....S/C
5. Basement use as per BBL 1983..... **N/A**
6. Emergency telephone no. board... **Displayed**
7. Generator set..... **No**

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no Letter No. F.6/DFS/MS/School/2012/1125 Dt. 28/02/2012. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]

[Handwritten Signature]
2016

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
28/2/12
ADD B/10