

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2016/WZ/ 608

Dated: 19/04/2016

**FIRE SAFETY CERTIFICATE**

Certified that the Building at Plot No. Girdhars International F-16, Udyog Nagar, Rohtak Road, New Delhi-110041 comprised of Basement, Ground Floor, Mezz, Floor, Ist Floor, IInd Floor Only, owned / occupied by Girdhars International, has already been issued Fire Safety Certificate vide letter No. F6/MS/DFS/2006/3189 dated 30/10/2006 in the name of: Girdhars International Pvt. Ltd. The premises was re-inspected by the officer concerned of Fire Service on 21.03.2016 in the presence of Sh. Surender (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Rule 33 of the Delhi Fire Service Rules, 2010 and that the Building / Premises is fit for Occupancy Class **Industrial** For a period of three years with effect from 19/04/2016 in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

  
(Dr. G.C. MISRA)

DIRECTOR

Issued on 19/04/16 at New Delhi by.



Copy To:

1. Sh. Devender Kamboj (General Manager). Girdhars International F-16, Udyog Nagar, Rohtak Road, New Delhi-110041

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to Non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Girdhars International F-16 ,Udyog Nagar,  
Rohtak Road, New Delhi-110041.
2. Type of Occupancy : Industrial ( Manufacturing of Candles )
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F6/MS/DFS/2006/3189 dated 30/10/2006
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/99/2769 dated 25/02/1999
6. Date of inspection : 21.03.2016
7. Name of the Inspecting Officer : A.K. Jaiswal
8. Name and designation of Officer  
from the building side : Sh.Surender (Manager)
9. Year of Construction : 1999
10. Applicant's letter No. : Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/ Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 Mtr.	Provided	MR
	• Gate width	4.5 Mtr.	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	1.25Mtr.	Provided	MR
	• Basements	1.25 Mtr.	Provided	MR
	c. Protection of exits			
	• Fire check door	Required (Basement)	Provided	MR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.25 mtr	1.25 mtr	MR

3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	8	10	MR
	• Types	ABC/Co2/Foam	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	One at each Floor	Provided	MR
	• Length of hose reel hose	30 mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8.	MOEFA	NR	NR	NR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR

11.	Internal Hydrants			
	• Size of riser/down- comer	150mm.	150mm.	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level / Over Head			
	• Discharge of main pump	Not mentioned in previous NOC	1620Lit./min.	MR
	➤ Head of main pump	Not mentioned in previous NOC	70MH	NMR
	➤ Number of main pumps	Not mentioned in previous NOC	2	MR
	➤ Jockey pump out put	Not mentioned in previous NOC	180 Lit./min.	MR
	➤ Jockey pump head	Not mentioned in previous NOC	70MH	NMR
	➤ Standby Pump out put	Not mentioned in previous NOC	1620Lit./min.	NR
	➤ Standby Pump Head	Not mentioned in previous NOC	70MH	NR
	➤ Auto Staring/Manual stopping	Required	NP	NMR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	Not mentioned in previous NOC	900 Lit./min.	MR
	➤ Head of the pump	Not mentioned in previous NOC	70MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	➤ Under ground tank capacity	50,000 Lts.	Provided	MR
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 Lts.	provided	MR

15.	Exit Signage	Not Mentioned in previous NOC	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	Not Mentioned in Recommendation	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Batter backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any:	NR	NR	NR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

11. In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/MS/DFS/2006/3189 dated 30/10/2006** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended

*Ak Jaiswal*  
21/3/16

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)