

C/75

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/Club/2016/ W2/605

Dated: 19/04/16

FIRE SAFETY CERTIFICATE

Certified that the **Shalimar Bagh Club** located at **Plot No – 9, B – Block Shalimar Bagh** comprised of Basement + Ground + 2 Upper Floors was granted NOC by this department vide letter no. F6/DFS/MS/Club/2013/181 dated 15-04-2013. The premises was re inspected by the officers concerned of this department on 29-03-2016 in the presence of Sh. Dharam Pal Gupta (President) of the Club and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010. Hence the NOC is renewed and premises is fit for Class D (Assembly) occupancy with effect from...19/04/16... for a period of three years subject to conditions printed below.

Issued on ...19/04/16..... at New Delhi by.


(Dr. G C Misra)
Director
Delhi Fire Service

Copy to:

1. Shalimar Bagh Club Plot No – 9, B – Block Shalimar Bagh.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

M-2A

INSPECTION REPORT

1. Name & address of the building: **Shalimar Bagh Club** located at **Plot No – 9, B – Block Shalimar Bagh.**
2. Type of Occupancy (Assembly) (Basement + Ground + 2 U Fs)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/Club/2013/181 Dated 15-04-2013.
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2000/913 dated 25-05-2000
6. Date of inspection : 29-03-2016
7. Name of the Inspecting Officer : Do West & ADO (WP)
8. Name and designation of Officer
 from the building side : Mr. Dharam Pal Gupta (President)
9. Year of Construction : 2005
10. Applicant's letter No. : Nil dated 08-03-2016

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtrs	Provided	MR
		5m	2x 390 cm Provided	MR(Being old Case)
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	1x130cm old case	1x130cm 1x98cm	MR(Being old Case)
	• Basements	1x290cm old case	1x290cm 1x98 cm	MR(Being old Case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 m	Provided	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30a/c par hour	Provided	MR
	<ul style="list-style-type: none"> • Upper floors 	12a/c par hour	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	18 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Heat & smoke	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	Ground floor	Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	One each floor	Provided	MR
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1		MR
	<ul style="list-style-type: none"> • Hose Box 	1	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	1620 lpm	Provided	MR
		40 mtr	Provided	MR
		1	Provided	MR
		250 LPM	Provided	MR
		40 mtr	Provided	MR
		1620 LPM	Provided	MR
		40 mtr	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50,000 ltr	Provided 50,000 ltr	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		12,500 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts Running from Ground to Second Floor			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

M-97

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/Club/2013/181 Dated 15-04-2013 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~110~~
30/3/16
Signature of the Inspecting Officer

~~31/3~~
Signature of the Inspecting Officer

Name Uday Vir Singh

Name Sonil Chaudhary

Designation ASO/WP

Designation DO/W

Dy C.F.O.

Director

vent 8/4

19/DFS/204
11/4/16.