

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/WZ/2016/ 628

Dated: 21/4/16

FIRE SAFETY CERTIFICATE

Certified that **Prince Public School** at Tikri Kalan, Delhi-110041, comprised of Ground + 1st Floor only owned / occupied by Prince Public School, has already been issued NOC / FSC by this department vide letter No. F6/DFS/MS/09/3248 dated 05/11/2009. The premises was re-inspected by the officer concerned of this department on 04.04.2016 in the presence of Sh. K.C. Malik (Chairman) and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Director of Education, GNCT of Delhi vide letter No. 262-362 dated 17.01.2005 and that the building / premises is fit for occupancy class **Educational (Group B)** with effect from 21/4/16.....for a period of 3 (three) years subject to conditions printed below.

Issued on 21/04/16 at New Delhi by.


(Dr. G.C.MISRA)
DIRECTOR.

o/c 

Copy to :-

1. Sh. K.C. Malik (Chairman), Prince Public School, Tikri Kalan, Delhi-110041.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to nonfunctional fire safety measure shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: **Prince Public School, Tikri Kalan, Delhi-110041.**
2. Type of Occupancy : **Educational (Ground+1st Floor only)**
3. Type of Case : **Renewal (Plot Area-2500 Yard²)**
(Total Covered Area-859yard²approx.)
4. Details of previous NOC : **F6/DFS/MS/09/3248 dated 05/11/2009**
5. Fire Safety directives Letter No. : **DOE Circular dated 17.01.2005**
6. Date of inspection : **04/04/2016**
7. Name of the Inspecting Officer : **A. K. Jaiswal**
8. Name and designation of Officer
from the building side : **Sh. K.C. Malik(Chairman)**
9. Year of Construction : **---2006**
10. Applicant's letter No. : **PPS/2016/004 dated 10/03/2016**

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circ. Dated 17/1/2005 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR
	• Basements	No basement	N/A	N/A
	b. Width of staircases			
	• Upper floors	05 ft	Provided	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	2	MR
	e. Width Of Corridor	1.50 mtr	Provided	MR
	f. Door Size	01 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	4	6	MR
	• Types	ISI marked	Provided	M/R

11/6				
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 MH	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A

N/7

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-A) General requirements for schools as per Director of Education circular dated 17/01/2005.

1. Escape route Clear.....
2. LPG cylinders in laboratories Nil.....
3. Electric wiring ... Conduit Wiring..... MCB and ELCB
Electric circuit
4. Electric meter board Not under the staircase.....
5. Basement use as per BBL 1983 NA.....
6. Emergency telephone no. board Displayed.....
7. Generator set..... Nil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/09/3248 dated 05/11/2009** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ak Jaiswal
4/4/16

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)