

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/GH/2016/MD2/616

Dated 21/04/16

FIRE SAFETY CERTIFICATE

Certified that the Sagar Mahadev Guest House is running at second floor and third floor of a building at D-126, South Ganesh Nagar, Delhi-92, which is comprises of basement, ground plus three upper floors. The basement is being used for storage and ground & first floor is being used for office and 07 guest rooms at second floors, 12 guest rooms at third floors respectively owned/occupied by M/S Sagar Mahadev Guest House was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/GH/2013/295 dated 15.05.2013. The Guest House was re-inspected by the officer concerned of this department on 12.04.2016 in the presence of Manager of the Guest House and found that the Guest house have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and found that the building SF+TF is fit for occupancy class "Residential Guest House" for 19 Rooms only, with effect from 21/04/16... for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on.....21/04/16.....at New Delhi by



(Rajesh Panwar)

Dy. Chief Fire Officer

Ph. 011-23412025

07c 88

To

Sagar Mahadev Guest House
D-126, South Ganesh Nagar, Delhi-92

Copy to-

The Joint Commissioner of police (Lic.),
1st Floor Police station, Defence Colony, New Delhi

Conditions

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This FSC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. Basement shall be used as a BBL.

INSPECTION REPORT

1. Name & address of the building : Sagar Mahadev Guest House, D-126, South Ganesh Nagar, Delhi-92
2. Building is comprised of : Guest house is running on **second floor & third floor** of the building which is comprised of basement, ground plus three upper floors .
3. Type of Occupancy : Residential
4. Type of Case : **Renewal**
5. Details of Previous FSC : F.6/DFS/MS/GH/2013/295 dated 15.05.2013
6. Fire Safety direction letter No : **Old Requirement**
7. Date of Inspection : 12.04.2016
8. Name of the Inspecting Officers: : Suresh Singh (ADO)
9. Name of the designation of Officer from the building side : Manager
10. Year of Construction : 2010
11. Applicant's letter No : 843/joint C.P. /Lic. (H) dated 18.03.2016

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement /BBL	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 no.	2 no.	MR
	Basement	1 no.	1 no.	MR
	B. Width of Staircases			
	Upper Floor	1 m	1.2 m, 1.1 m	MR/Old Case
	Basement	1 m	1 m	MR
	c. Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
g. Width of Corridor	NA	NA	NA	
h. Door Size	1 m	1 m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basement	NA	NA	NA
	• Upper floor	NA	NA	NA

5.	Fire Extinguisher			
	• Total numbers	06 no.	06 no.	MR
	• Types	CO ₂ +ABC	CO ₂ +ABC	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	NA	NA	NA
	Location of main panel	NA	NA	NA
	Location of repeater panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters's location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	NA	NA	NA
	upper floor	NA	NA	NA
	sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
12	Yard Hydrants.			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump	900 LPM	180 & 225 LPM	MR
	➤ Head of the Pump	40 m	40 & 60 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	10,000 Liters	10,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication in lift car	NA	NA	NA
	Firemen's grounding switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	Total area	NA	NA	NA
	Location	NA	NA	NA
19	Fire Control Room			
	Detector system panel	NA	NA	NA
	Flow switch panel	NA	NA	NA
	PA system panel	NA	NA	NA
	Batter backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter no. F.6/DFS/MS/GH/2013/295 dated 15.05.2013 renewal under Rule 35 of the Delhi Fire Service Rules 2010 is recommended.

S Singh
12.4.16

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO (Shah)

DO (EAST)

Submitted for approval please.

Dy CFO (NDZ)

S Singh
13/4/16