

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**  
**Fax: 23412593, Email:gargatul@hotmail.com, Tel:- 011-26189168**

NO.F6/ DFS/MS/SZ/School/2016/ 625

Dated: 21/4/16

**FIRE SAFETY CERTIFICATE**

Certified that SDMC Co-Ed School, located at Sant Nagar, New Delhi-110065, comprised of old block- ground floor only and new block - ground plus one upper floor owned/occupied by SDMC of Delhi was granted FSC by this department vide letter no. F6/DFS/MS/School/2014/193 dated 06/02/2014. The school building was re-inspected by the officer concerned of this department on 01/04/2016 in the presence of Mr. Shakeel Ur Rehman and found that the school building have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 issued by the Directorate of Education dated 01-03-2011 and that the school building is fit for occupancy class "Educational"(School) with effect from the date of issue ...21/4/16.... of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on 21/4/16 at New Delhi by.

(ATUL GARG)

DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

The Principal  
SDMC Co-Ed School,  
Sant Nagar, New Delhi-110065.

**Conditions for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building:- SDMC. Co-Education School, Sant Nagar, New Delhi-110065
2. Type of occupancy:- Educational (School)
3. Type of case: - Renewal
4. Details of previous NOC: - F6/DFS/MS/School/2014/SZ/193 Dated 06/02/14
5. Fire safety directives No.- F.16/Estate/CC/Fire/Safety/2011/3298to3398 dated 01/03/2011
6. Date of inspection:- 1/4/2016
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mr. Shakeel Ur Rehman
9. Year of construction:- 1971 & 2015
10. Applicant's letter No:- Nil dated 12/02/2016
11. Composition of building: - School is in two blocks Old block-Ground floor only & New block-Ground Plus One Upper Floor.

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	9mtr	Provided	MR
	2) Gate width	Required	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	01no	02no	MR ✓
	2. Basements	N/A	N/A	N/A ✓
	B. Width of staircase			
	1. Upper floors	1.50mtr	1.50mtr each	MR ✓
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01no	Provided	MR
	E. Width of corridor	1.5m	1.92m	MR ✓
	F. Door size	1m	1m	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	10 Nos	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR

<b>6.</b>	<b>First-Aid Hose Reel</b>		
	1) Total number of each floor	N/A	N/A
	2) Length of hose reel hose	N/A	N/A
	3) Nozzle diameter	N/A	N/A
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>		
	1) Type of detectors	N/A	N/A
	2) Location of main panel	N/A	N/A
	3) Location of repeater panel	N/A	N/A
	4) Alternate source of power	N/A	N/A
	5) Hooter's Location	N/A	N/A
<b>8.</b>	<b>MOEFA</b>		
<b>9.</b>	<b>Public Address System</b>		
<b>10.</b>	<b>Automatic Sprinkler System</b>		
	1) Basement	N/A	N/A
	2) Upper floors	N/A	N/A
	3) sprinkler above false ceiling	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>		
	1) Size of riser/down-comer	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A
	3) Hose box	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>		
	1) Total number of hydrants	N/A	N/A
	2) Hose box	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>		
	<b>1) Ground level</b>		
	a) Discharge of main pump	N/A	N/A
	b) Head of main pump	N/A	N/A
	c) Number of main pump	N/A	N/A
	d) Jockey pump out put	N/A	N/A
	e) Jockey pump head	N/A	N/A
	f) Stand by pump output	N/A	N/A
	g) Stand by pump head	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A
	<b>2) Terrace level</b>		
	a) Discharge of pump	N/A	N/A
	b) Head of pump	N/A	N/A
	c) Power supply	N/A	N/A
	d) Auto starting of pump	N/A	N/A
	<b>14. Captive Water Storage for Fire Fighting</b>		
	1) Underground tank capacity	N/A	N/A
	a) Draw-off connection	N/A	N/A
	b) Fire service inlet	N/A	N/A
	c) Access to tank	N/A	N/A
	d) Over head tank capacity	N/A	N/A
<b>15.</b>	<b>Exit Signage.</b>		
		Required	Provided
			MR

017

<b>16. Provision of Lifts.</b>			
a) Pressurization of lift shaft	N/A	N/A	N/A
b) Pressurization of lift lobby	N/A	N/A	N/A
c) Communication in lift car	N/A	N/A	N/A
d) Fireman's switch	N/A	N/A	N/A
e) Lift signage	N/A	N/A	N/A
<b>17. Stand by Power Supply</b>	N/A	N/A	N/A
<b>18. Refuge Area</b>	N/A	N/A	N/A
Total area location	N/A	N/A	N/A
<b>19. Fire Control Room</b>	N/A	N/A	N/A
a) Detector system panel	N/A	N/A	N/A
b) Flow switch panel	N/A	N/A	N/A
c) PA system panel	N/A	N/A	N/A
d) Battery backup	N/A	N/A	N/A
e) Building floor plan	N/A	N/A	N/A
<b>20. Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

Keeping in view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Education Department vide Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01-03-2011, renewal of fire safety certificate issued vide letter no.F6/DFS/MS/School/2014/193 dated 06/02/2014 is recommended.

Accordingly DFA is put up for sign pl.

*D.B. Mukherjee*  
6/4/2016

Signature of the inspecting officer

Name: - D.B.Mukherjee.

Designation:- Assistant Divisional Officer (BCP)

~~DO (South)~~

7/4/16