

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/EH/S2/2016/183

Dated: 25/04/16

**FIRE SAFETY CERTIFICATE**

Certified that M/S Swagath Restaurants, located at 13-14, Defence Colony, New Delhi-110024, comprised of basement for storage only, ground plus two upper floors, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2013/183, dated 16-04-2013. The premises was re-inspected by the officer concerned of this department on 07-04-2016 in the presence of Sh. Shridhar (Manager) and found that the said eating house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class assembly (Eating House) with effect from ...25/04/2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...25/4/..... 2016 at New Delhi by.

  
(Atul Garg)

Dy. Chief Fire Officer

T.No.011-26189168

To:-M/S Swagath Restaurants, located at 13-14, Defence Colony, New Delhi-110024.

**Conditions for the validity of fire safety certificate are as under:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : M/S Swagath Restaurants, located at 13-14, Defence Colony, New Delhi-110023.
2. Building is comprised of :Basement-Storage only, Ground plus two upper floors.  
(Restaurant at Ground plus two upper floors in No.14 & 1<sup>st</sup> and 2<sup>nd</sup> floors In No.13. Both are interconnected)
3. Type of Occupancy : Eating House (Assembly Building).
4. Type of Case : Old Case
5. Details of Previous NOC : No.F.6/DFS/MS/EH/2013/1834, dated-16.04.2013.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection :07.04.2016
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of officer from the building side : Sh. Shridhar (Manager).
10. Year of Construction : 2002.
11. Applicant's letter No. : Nil, dated 25.02.16.

| S.N                  | Minimum Standards on fire prevention and fire safety U/R33 | Old NOC Requirements   | Provided at Site       | Remarks      |
|----------------------|--|------------------------|------------------------|--------------|
| 1                    | Access to building   |                        |                        |              |
|                      | Road width   | 6 m                    | 10 m                   | MR           |
|                      | Gate width   | N.A.                   | N.A.                   | N.A.         |
|                      | Width of internal road                                     | N.A.                   | N.A.                   | N.A.         |
| 2                    | Number, Width, Type and Arrangement of Exits.              |                        |                        |              |
|                      | a. Number of Staircases                                    |                        |                        |              |
|                      | Upper Floor  | 02nos.                 | 02nos.                 | MR           |
|                      | Basement   | 02nos.                 | 02nos.                 | MR           |
|                      | B. Width of Staircases                                     |                        |                        |              |
|                      | Upper Floor  | 1.2m/70cm              | 1.2m & 70cm            | MR(old case) |
|                      | Basement   | 1.2m/70cm              | 1.2m & 70cm            | MR(old case) |
|                      | c. Protection of exits                                     |                        |                        |              |
|                      | Fire check door  | N.A.                   | N.A.                   | N.A.         |
|                      | Pressurization   | N.A.                   | N.A.                   | N.A.         |
|                      | e. No. of continuous staircases to terrace.                | N.A.                   | N.A.                   | N.A.         |
| g. Width of Corridor | 1no.   | 1no.                   | MR                     |              |
| h. Door Size         | N.A.   | N.A.                   | N.A.                   |              |
|                      | 102cm & 90cm   | 102cm & 90cm           | MR(old Case)           |              |
| 3                    | Compartmentation   |                        |                        |              |
|                      | Fire check door  | N.A.                   | N.A.                   | N.A.         |
|                      | Sealing of electrical shafts                               | Required               | Provided               | MR           |
|                      | Fire rating of shaft door                                  | N.A.                   | N.A.                   | N.A.         |
|                      | Water curtain  | N.A.                   | N.A.                   | N.A.         |
|                      | Fire Dampers   | N.A.                   | N.A.                   | N.A.         |
| 4                    | Smoke Management System.                                   |                        |                        |              |
|                      | Basement   | 30a/c per hour         | Exhaust fans Provided  | MR           |
|                      | Upper floor  | 12 a/c per hour        | Exhaust fan Provided   | MR           |
| 5.                   | Fire Extinguisher  |                        |                        |              |
|                      | Total numbers  | 16 nos.                | 16 nos.                | MR           |
|                      | types  | WCO <sub>2</sub> & ABC | WCO <sub>2</sub> & ABC | MR           |
|                      | IS marking   | ISI marked             | ISI marked             | MR           |
| 6                    | First-aid-Hose Reels.                                      |                        |                        |              |
|                      | Total numbers of each floor                                | 01no.                  | 01no.                  | MR           |
|                      | Length of hose reel hose                                   | 30 m                   | 30m                    | MR           |
|                      | Nozzle diameter  |                        |                        |              |

|    |   |                   |                   |      |
|----|---|-------------------|-------------------|------|
| 7  | Automatic fire detection and alarming system. |                   |                   |      |
|    | Type of detectors                             | N.A.              | N.A.              | N.A. |
|    | Location of main panel                        | N.A.              | N.A.              | N.A. |
|    | Location of repeater panel                    | N.A.              | N.A.              | N.A. |
|    | Alternate source of power                     | N.A.              | N.A.              | N.A. |
|    | Hooters                                       | N.A.              | N.A.              | N.A. |
| 8  | MOEFA   | Required          | Provided          | MR   |
| 9  | Public address System.                        | Required          | Provided          | MR   |
| 10 | Automatic Sprinkler System.                   |                   |                   |      |
|    | Basement floor                                | Required          | Provided          | MR   |
|    | upper floor                                   | Required          | Provided          | MR   |
|    | sprinkler above false ceiling                 | N.A.              | N.A.              | N.A. |
| 11 | Internal Hydrants                             |                   |                   |      |
|    | size of riser/down-comer                      | 100mm             | 100mm             | MR   |
|    | Number of hydrants in all floors              | 01no.             | 01no.             | MR   |
|    | Hose Box                                      | 01no.             | 01no.             | MR   |
| 12 | Yard Hydrants.                                |                   |                   |      |
|    | Total number of hydrants                      | N.A.              | N.A.              | N.A. |
|    | Hose Box                                      | N.A.              | N.A.              | N.A. |
| 13 | Pumping Arrangements.                         |                   |                   |      |
|    | • Ground Level                                | N.A.              | N.A.              | N.A. |
|    | ➤ Discharge of main Pump                      | N.A.              | N.A.              | N.A. |
|    | ➤ Head of Main Pump                           | N.A.              | N.A.              | N.A. |
|    | ➤ Number of main pumps                        | N.A.              | N.A.              | N.A. |
|    | ➤ Jockey pump out put                         | N.A.              | N.A.              | N.A. |
|    | ➤ Jockey pump head                            | N.A.              | N.A.              | N.A. |
|    | ➤ Standby pump out put                        | N.A.              | N.A.              | N.A. |
|    | ➤ Standby pump Head                           | N.A.              | N.A.              | N.A. |
|    | ➤ Auto Starting /Manual stopping              | N.A.              | N.A.              | N.A. |
|    | ➤ Pump House Access                           | N.A.              | N.A.              | N.A. |
|    | • Terrace Level                               | Required          | Provided          | MR   |
|    | ➤ Discharge of pump                           | 450 lpm & 180 lpm | 450 lpm & 180 lpm | MR   |
|    | ➤ Head of the Pump                            | 40m               | 40m.              | MR   |
|    | ➤ Power supply                                | Required          | Provided          | MR   |
|    | ➤ Auto Starting of pump                       | Required          | Provided          | MR   |
| 14 | Captive Water Storage for Fire Fighting.      |                   |                   |      |
|    | Underground tank capacity                     | N.A.              | N.A.              | N.A. |
|    | Draw-off connection                           | N.A.              | N.A.              | N.A. |
|    | Fire service inlet                            | N.A.              | Provided          | N.A. |
|    | Access to tank                                | N.A.              | N.A.              | N.A. |
|    | Overhead Tank capacity                        | 5000Ltrs.         | 5000Ltrs.         | MR   |
| 15 | Exit Signage.                                 | Required          | Provided          | MR   |
| 16 | Provision of Lifts.                           |                   |                   |      |
|    | Pressurization of Lift Shaft                  | N.A.              | N.A.              | N.A. |
|    | Pressurization of Lift lobby                  | N.A.              | N.A.              | N.A. |
|    | Communication in lift car                     | N.A.              | N.A.              | N.A. |
|    | Firemen's grounding switch                    | N.A.              | N.A.              | N.A. |
|    | Lift Signage                                  | N.A.              | N.A.              | N.A. |
| 17 | Standby power supply                          | Required          | D.G. Set          | MR   |
| 18 | Refuge Area.                                  |                   |                   |      |
|    | Total area                                    | N.A.              | N.A.              | N.A. |
|    | Location                                      | N.A.              | N.A.              | N.A. |

N/14

M/S Swagath Restaurants, located at 13-14, Defence Colony, New Delhi.

|    |   |      |      |      |
|----|---|------|------|------|
| 19 | Fire Control Room   |      |      |      |
|    | Detector system panel   | N.A. | N.A. | N.A. |
|    | Flow switch panel   | N.A. | N.A. | N.A. |
|    | PA system panel   | N.A. | N.A. | N.A. |
|    | Batter backup   | N.A. | N.A. | N.A. |
|    | Building Floor Plans  | N.A. | N.A. | N.A. |
| 20 | Special Fire Protection systems for of special Risks, if any: | N.A. | N.A. | N.A. |

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/EH/2013/183, dated 16.04.2013 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for kind consideration please.



13/4/16

Signature of the Inspecting Officer

Name : Vedpal

Designation : Assistant Divisional Officer

D.O. (South)



13/4/16