

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI**

No. F6/DFS/MS/2016/W2/639

Dated: 26/04/16

FIRE SAFETY CERTIFICATE

Certified that the **Shalimar Place** located at **Plot No – 1, District Centre Shalimar Bagh**, comprised of Basement + Ground + 2 Upper Floors was granted FSC by this department vide letter no F6/DFS/MS/DC/2013/119 Dated 26-03-2013. The premises was re-inspected by the officers concerned of this department on 07-04-2016 in the presence of Sh. Gagan set of and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010. Hence the FSC is renewed and premises is fit for Class F (Mercantile) occupancy with effect from...26/04/16... for a period of three years subject to conditions printed below.

Issued on...26/04/16...at New Delhi by.


(Dr.G.C.Misra)

Director,

Delhi Fire Service

Tel:-011-23414000

Copy to:

1. Shalimar Place, Plot no – 1, District Centre Shalimar Bagh.

Following fire safety directives must be adhere to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The basement shall be used strictly as per building bye laws.
7. The owner / occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

2. Name & address of the building: **Shalimar Place** located at **Plot No - 1, District Canter Shalimar Bagh.**
3. Type of Occupancy : (Mercantile) (Basement + Ground + 2 U Fs)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/DC/2013/119 Dated 26-03-2013.
6. Fire Safety directives Letter No. : F6/DFS/MS/BP/2007/1288 dated 08-05-2007
7. Date of inspection : 07-04-2016
8. Name of the Inspecting Officer : Do West & ADO (WP)
9. Name and designation of Officer
from the building side : Mr. Gagan set
10. Year of Construction : 2007-2008
11. Applicant's letter No. : Nil dated - Nil

S No	Minimum standards on fire prevention and fire safety U/R	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtrs	Provided	MR
	• Gate width	4.5mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	5	Provided	MR
	• Basements	5	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr each	5x148cm	MR (Old Case)
	• Basements	1.5 mtr each	5x148cm	MR (Old Case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace			
	• 1.5 mtr each		Provided	MR
	e. Width Of Corridor			
	• 1.5 mtr each		Provided	MR
	f. Door Size			

3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	40 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	3	05 Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	each floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants:			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	3	05 provided	MR
	• Hose Box	3	05 Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	4	Provided	MR
	• Hose Box	4	Provided	MR

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 lpm & 180 lpm	Provided	MR
		40 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		25,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR

4/13

20.	Special Fire Protection Systems for Protection of special Risks, if any;	Co2 flooding	Provided	MR
-----	--	--------------	----------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS//DC/2013/119 Dated 26-03-2013 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature~~
4/14/16

Signature of the Inspecting Officer

~~Signature~~
12/11

Signature of the Inspecting Officer

Uday Vir Singh

Name

Shudhanshu Chaudhary

Designation

SO

Designation

ASD/WP