

FIRE SAFETY CERTIFICATE

Certified that the M/S "Shreyans Inn" guest house located at B-2/5, Safdarjung Enclave, New Delhi-110029, comprised of basement (storage only), stilt (reception), ground floor (9guest rooms), 1st floor (09guest rooms) & 2nd floor (09guest rooms), total 27 guest rooms, owned/occupied by M/S "Shreyans Inn" guest house, was granted FSC by this department vide letter No. F6/DFS/MS/GH/2013/96, dated 19-03-2013. The premises was re-inspected by the officer concerned of this department on 18-04-2016 in the presence of Sh. Harsh Gupta, Manager and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential (guest house with 27 guest rooms only) with effect from 26/04/2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/04/2016 at New Delhi by.


(Atul Garg)

Dy. Chief Fire Officer

T.No.011-26189168

Copy to:- 1. Joint Commissioner of Police, Licensing Branch, 1st floor, P.S. Defence Colony, New Delhi.

2. M/S "Shreyans Inn" guest house located at B-2/5, Safdarjung Enclave, New Delhi.

Conditions for the validity of fire safety certificate are under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/S "Shreyans Inn" guest house located at B-2/5, Safdarjung Enclave, New Delhi-110029.		
2	Type of Occupancy	Residential, Lodging House "A"		
3	Building Comprised of	Basement=Storage, Stilt, Ground plus two upper floors. Stilt=Reception, GF=9Guest Rooms, 1st floor = 09 Guest Rooms & 2nd floor=09 Guest Rooms. Total=27 Guest Rooms.		
4	Type of case	Renewal		
5	Details of previous NOC	No.F6/DFS/MS/GH/2013/96, Dated 19.03.2013.		
6	Fire safety directives letter No	Nil.		
7	Date of inspection	18.04.2016		
8	Name of the inspecting Officers	Vedpal ADO		
9	Name and designation of officers			
10	from the building side	Sh. Harsh Gupta, Manager.		
11	Year of construction			
	Applicant's letter No.	No.918/Joint C.P./Lic (H), Dt 23.03.2016.		

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per old NOC	Provided at site	Remarks MR / NMR
--------	---	----------------------------	------------------	------------------

1	Access to building			
----------	---------------------------	--	--	--

	1) Road width	Required	12m Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
----------	--	--	--	--

	a. Number of staircases			
	1. Upper floors	01no.	01no.	MR
	2. basements	02nos.	02nos.	MR
	b. Width of staircase			
	1. Upper floors	1.25 Mtr	1.35Mtrs..	MR
	2. basements	1.25m/80cm	1.25m & 80cm	MR(old case)
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	1 No. Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr	1Mtr.	MR

3	Compartmentation.			
----------	--------------------------	--	--	--

	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
----------	---------------------------------	--	--	--

	Basement	30 a/c per hour	Exhaust fans Provided	MR
	Upper floors	12 a/c per hour	Natural Ventilation	MR

5	Fire Extinguishers			
----------	---------------------------	--	--	--

	Total numbers		20 Nos.	MR
	Types		ABC, Co2,	MR
	ISI marking	ISI	Yes	MR

6	First-Aid Hose Reels.			
----------	------------------------------	--	--	--

	Total numbers on each floor	01no.	01no.	MR
	Length of Hose reel hose	30 m	30m	MR
	Nozzle Diameter	5 mm	5mm	MR

	Type of detectors	N/A	N/A	N/A
	Location of Main Panel	N/A	N/A	N/A
	Location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	Upper floors	N/A	N/A	N/A
	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	150mm	150mm	MR
	Number of Hydrants per floor	01no.	01no.	MR
	hose Box	01no.	01no.	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450+180LPM	450+180LPM	MR
	b. head of the pump	40m	40m(each)	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 ltr	10000Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.		Not Required	
	total area			
	location			
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/GH/2013/96, dated 19.03.13 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

18/4/16

Signature of the inspecting officer

Name Vedpal

Designation : Assistant Divisional Officer

~~D.O. (South)~~

21/4/16

~~Dy CPO (SZ)~~
22/4/16

Dy CPO 03
22/4/16

~~DIRECTOR/DCS~~

22/4

MS

FT letter is put up for sign please

~~Dy CPO (SZ)~~

26/4/16

26/4/16
ADD (SZ)