

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/2016/SZ/ 657

Dated: 27/04/16

FIRE SAFETY CERTIFICATE

Certified that the VISHVAS (Meditation Temple) H.A.F. Pocket-01, Sector-13, Dwarka, New Delhi, comprised of Stilt plus two upper floors owned/occupied by VISHVAS (Meditation Temple) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 12.4.2016 in presence of Sh. Anand Bharti (representative) and that the building is fit for occupancy class D "Assembly building" (Temple) with effect from...27/4/16... for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on ...27/4/16... at New Delhi by


(Atul Garg)

Dy.Chief Fire Officer
Ph.011-26189168

Copy to,

1. The Jt. Director (L&I) Bldg. DDA Building Section Vikas Sadan, INA, New Delhi.
2. Authorized Signatory, VISHVAS, 1, North West Avenue, Punjabi Bagh, New Delhi-110026.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/S VISHVAS (Meditation Temple) H.A.F. Pocker-01, Sector-13, Dwarka, New Delhi.		
2	Type of Occupancy	Assembly Building "D"		
3	Type of case	New		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	F6/DFS/MS/BP/2015/247 Dated 7.9.2015		
6	Date of inspection	12.4.2016		
7	Name of the inspecting Officers :	DO Sanjay Kumar Tomar, ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Anand Bharti (Representative)		
9	Year of construction	2015	Stilt & Two Upper Floors	
10	Applicant's letter No.	Nil 21.12.2015		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	12 Mtrs.	12 Mtrs.	MR ✓
	2) Gate width	4.5 Mtr.	4.5 Mtrs.	MR ✓
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR ✓
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	2 & 1.5 Mtrs.	2 & 1.5 Mtrs.	MR ✓
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	One	MR ✓
	e. Width of corridor	2.01 Mtrs.	2.5 Mtrs.	N/A
	f. Door size	2 Mtrs.	2 Mtrs.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Provided	MR ✓
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	total numbers	6 Nos.	8 Nos.	MR ✓
	Types	Co2 OR ABC	ABC,	MR ✓
	ISI marking	ISI	ISI	MR ✓

	total numbers on each floor	One	One	MR ✓
	Length of Hose reel hose	30 Mtrs.	30 Mtrs.	MR ✓
	Nozzle Diameter	5 mm.	5 mm.	Mr ✓
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	100 MM	MR ✓
	Number of Hydrants per floor	One	One	MR ✓
	hose Box	Required	Provided	MR ✓
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	450 LPM	MR ✓
	b. head of the pump	30 Mtrs.	30 Mtrs.	MR ✓
	c. Power supply	Required	Provided	MR ✓
	d. Auto starting of pump	Required	Provided	MR ✓
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10,000 Ltrs.	10,000 Ltrs.	MR ✓
15	Exit Signage.	Required	Provided	MR ✓
16	Provision of lifts.			
		Yet not Installed		
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	DG Set 62KVA	MR ✓

4/12

18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	ABC		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly DFA is put up for your approval and signature please.


18/4/16

Signature of the Inspecting Officer-II

Name Sanjay Kumar Tomar


Designation Divisional Officer



Signature of the inspecting officer

Name S.P. Bhardwaj

Designation : ADO (Dwarka)


22/4/16