

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**


No.F6/DFS/MS/EH/2016/ N02/669

Dated :- 28/04/16

FIRE SAFETY CERTIFICATE

Certified that the **M/s Cafe MRP (A Unit of RSV Hospitality (P) Ltd)** located at **C-39,1st Floor,Cannaught Place,New Delhi** comprised of **Ground + 2 upper floor but restaurant is running on 1st floor only** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on **22/04/16** in the presence of **Mr. Sumit Gupta (Owner)** that the premises is fit for occupancy of class **Assembly Building Group-D Restaurant** with effect from ~~28/04/16~~ for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,mentioned below.

Issued on ...28/04/16..... at New Delhi by.


(Rajesh Panwar)
Dy. Chief Fire Officer
Delhi Fire Service
Ph – 011-23412025

- Copy to:- (1) Medical Officer of Health,
New Delhi Municipal Council,
Palika Kendra, New Delhi.
- (2) M/s Cafe MRP (A Unit of RSV Hospitality (P) Ltd),
C-39,1st Floor,Cannaught Place,New Delhi.

Conditions:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

- 11-2

INSPECTION REPORT

- 1. Name & address of the building:- M/s Cafe MRP (A Unit of RSV Hospitality (P) Ltd), C-39, 1st Floor, Cannaught Place, New Delhi.
- 2. Type of occupancy:- Assembly Building Group D, Ground + 2 upper floor (Restaurant is on 1st floor only)
- 3. Type of case:- Fresh.
- 4. Details of previous FSC: - No.
- 5. Fire safety directives No.- N/A
- 6. Date of inspection:- 22 /04/16
- 7. Name of the inspecting officer:- D.O. Gurmukh Singh & A.D.O. Manoj Kumar Sharma
- 8. Name & designation of officer From the building side:- Mr. Sumit Gupta (Owner)
- 9. Year of construction:- Heritage building.
- 10. Applicant's letter No:- MOH/D-789/(Lic.)/SI-I dated 07/04/16

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	6 mtr.	18 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors (Mezz.)	02 nos.	02 nos.	MR
	2. Basements	NA	NA	NA
	B. Width of staircase			
	1. Upper floors (Mezz.)	1 mtr.	1.01 mtr. & 1.07 mtr.	MR
	2. Basements	NA	NA	NA
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 Mtr.	2 Mtr. & 1 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	NA	NA

h
Mew

	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	06 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 &	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 no.	01 no.	MR
	2) Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System /Intercom	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm.	100 mm.	MR
	2) Number of hydrants per floor	01 no.	01 no.	MR
	3) Hose box	01 no.	01 no.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 Mtr.	40 Mtr.	MR
	c) Power supply	Required	Provided	MR

h

MR

- 2-4

	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 Ltr.	10,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection. Being heritage building width of staircase is considered as it cannot increased / changed. 4

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate, under rule 35 of the Delhi Fire Service Rules 2010, is recommended please.

Gurmukh Singh
 Gurmukh Singh
 Divisional Officer

Manoj Kumar Sharma
 Manoj Kumar Sharma
 Assistant Divisional Officer

Dy CEO / (ADZ)