

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2016/SZ/ 675

Dated: 28/04/16

FIRE SAFETY CERTIFICATE

Certified that the Government Senior Secondary School at Sector-17, Dwarka, New Delhi, comprised of ground plus three upper floors owned/occupied by Delhi Government have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of Fire Service on 22.4.2016 in presence of Sh. V K Pandey (Principal) and that the building/premises is fit for occupancy class B "Educational building" with effect from 28/04/16 for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 28/04/16 at New Delhi by

(Atul Garg)

Dy. Chief Fire Officer
Ph.011-26189168

Copy to,

1. Dy. Director, Education) Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.
2. Executive Engineer (E) PWD Edu. M-1, ITI Campus, Pusa, New Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

N/2

INSPECTION REPORT

1	Name & address of the building	Government Senior Secondary School at Sector-17, Dwarka, New Delhi.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	F6/DFS/MS/HQ/2012/92 dated 07.01.2013		
6	Date of inspection	22.4.2015		
7	Name of the inspecting Officer	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. V.K. Pandey		
9	Year of construction	2016		
10	Applicant's letter No.	54 (Pucca School)/Dwarka/EE(E) Edu.M1/15-16/95	Ground Plus Three upper Floors ✓	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	30 Mtrs.	30 Mtrs.	MR ✓
	2) Gate width	6 Mtrs.	6 Mtrs.	MR ✓
	3) Width of internal road	N/A	6 Mtrs.	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	4 Nos.	4 Nos.	MR ✓
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtr.	1.5 Mtrs.	MR ✓
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	4 Nos.	4 Nos.	MR ✓
	e. Width of corridor	1.51 Mtrs.	1.51 Mtrs.	MR ✓
	f. Door size	1 Mtr.	1 Mtr.	MR ✓
3	Compartmentation.			
	1. Fire check door	Required	Provided in lift lobby	MR
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A


5	Fire Extinguishers			
	total numbers	4 Nos. Each Floor	32 Nos.	MR ✓
	Types	Co2 OR ABC	Co2 & ABC	MR ✓
	ISI marking	ISI Marked	Provided	MR ✓
6	First-Aid Hose Reels.			
	total numbers on each floor	4 Nos.	4 Nos.	MR ✓
	Length of Hose reel hose	30 m	30 m	MR ✓
	Nozzle Diameter	5 mm	5 mm	MR ✓
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	100 mm	N/A
	Number of Hydrants per floor	N/A	4 Nos.	N/A
	hose Box	N/A	Provided	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	6 Nos.	N/A
	hose box	N/A	Provided	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	450 LPM (2 Nos.)	MR ✓
	b. head of the pump	40 m	40 m	MR ✓
	c. Power supply	Required	Provided	MR ✓
	d. Auto starting of pump	Required	Provided	MR ✓
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	75000 Ltrs.	N/A
	a. Draw-off connection	N/A	Provided	N/A
	b. fire service inlet	N/A	Provided	N/A
	c. Access to tank	N/A	Provided	N/A
	Over head tank Capacity	10,000 Ltrs.	10,000 Ltrs.	MR ✓
15	Exit Signage.	Required	Provided	MR ✓

16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
17	Standby power supply	Required	DG Set 63 KVA	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	Co2 & DCP		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Auditorium without fixed seats at 3rd floor is provided with two exits having 2 meters width.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rules, grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Act 2007 & Rules 2010 is recommended.

Accordingly DFA is put up for approval and signature please.


Signature of the Inspecting Officer
 Name S.P. Bhardwaj
 Designation ADO (Dwarka)

~~DO~~
~~(F) 26/4/16~~
~~Dy CFO (F3)~~
~~27/4/16~~
~~DIRECTOR/DF~~

For letter is put up for signature please.

~~28/4/16~~
