

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/Banquet/2016/02/687 Dated: 28/04/16

FIRE SAFETY CERTIFICATE

Certified that the J.R.P.Vatika Banquet Hall running at First & Second floor of building at C-25,Acharya Niketan,Opp.Mayur Vihar-1, Delhi -92,owned /occupied by J.R.P.Vatika Banquet Hall,comprised of ground ,mezzanine plus two upper floors was granted fire safety certificate vide letter no.F6/DFS/MS/Banquet/2013/294 dated 14.05.2013.The building was inspected by the officer concerned of this department on 21.04.2016 in the presence of Sh.Surinder Singh Gulati and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 and that the first & second floor of building is fit for occupancy Group "Assembly Building/Banquet " with effect from ..28/04/16.... for a period of three years, subject to conditions printed overleaf.

Issued on ..28/04/16... at New Delhi by



(Rajesh Panwar)
Dy.Chief Fire Officer
Ph. 011-23412025

To,
J.R.P.Vatika Banquet Hall
C-25,Acharya Niketan,Opp.Mayur Vihar-1,
Delhi -92

Copy to:-
The Dy. Health Officer,
East Delhi Municipal Corporation ,Health Department,
Shahdara (South) Zone, Karkardooma, Shahdara, Delhi

o/c

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized if any.
6. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : J.R.P. Vatika Banquet Hall at first & Second floor at C-25, Acharya Niketan, Opp. Mayur Vihar-1, Delhi -92.

2. Type of Occupancy : Assembly

3. Type of Case : Renewal

4. Details of Previous FSC : F.6/DFS/MS/Banquet/ 2013/294 dated 14.05.13

5. Fire Safety directives No : F.6/DFS/MS/BP/2013/39 dated 31.01.13

6. Date of Inspection : 21.04.16

7. Name of the Inspecting Officer : ADO R.K.Yadav

8. Name of the designation of Officer
From the building side : Mr.Surender Singh Gulati (Owner)

9. Year of Construction : 1999

10. Applicant's letter No : 13.04.16

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	12 Mtrs N/A N/A	13.5 Mtrs. N/A N/A	MR N/A N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 	02 Nos N/A	02 Nos. N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 	1.5 M N/A	1.5 & 1.4 M N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required N/A	Provided N/A	MR N/A
	e. No. of continuous staircases to terrace	2 No. N/A	2 No. N/A	MR N/A
	g. Width of Corridor	2.0 Mtr.	2 no. of 2 M	MR
	h. Door Size			
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers 	Required Required N/A N/A N/A	Provided Sealed N/A N/A N/A	MR MR N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A Required	N/A Provided	N/A MR
5.	Fire Extinguisher			
	<ul style="list-style-type: none"> Total numbers types IS marking 	04 no. ABC & Co2 ISI marked	14 No. ABC & Co2 ISI marked	MR MR MR
6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> Total numbers of each floor Length of hose reel hose Nozzle diameter 	1 no. 30 m 5 mm	Provided Provided Provided	MR MR MR

7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters's location	Different Location	Different Location	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15000 Ltrs.	15000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The fire safety certificate issued vide letter no. :F.6/DFS/MS/Banquet/2013/294 Dated 14.05.13 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

R. K. Yadav

Signature of the Inspecting Officer ^{25/4/2016}
 Name:-R.K.Yadav
 Designation :-ADO(L.N)

DO/ED)

Submitted for approval please.

Dy CFO (ND2)

R. K. Yadav
25/4/16

[Signature]
25/4

Director
[Signature]
25/4

NS

Su, FT helter is put up for signature pl.

[Signature]
25/4/2016

Dy CFO (ND2)
[Signature]
29/4

RDW