


FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
(SEE SUB -RULE (1) OF RULE 35)
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE: NEW DELHI-110001
No.F.6/DMS/MS/EH/2016/w21685 dated: 29/04/16

FIRE SAFETY CERTIFICATE

Certified that the 02 Multicuisine located on (Ground + First Floor) A-23, Block A&B, NN Towers, Community Centre, Road No.44, Pitampura, Delhi - 110034 was issued FSC vide letter No. F.6/DFS/MS/EH/09/2769 dated 10.09.2009. The Aggarwal Millenium Tower, E-1,2,3, Netaji Subhash Place, Pitampura, Delhi-110034 has already issued FSC vide letter No. F.6/DMS/MS/EH/2013/194 dated 23.04.2013. The premises was re-inspected by the officers concerned of this department on 13.04.2016 in the presence of Mr.M.S. Rana (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 29/04/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service rule, 2010.

Issued on 29/04/16 at New Delhi by


(Dr.G.C.MISRA)
Director
Delhi Fire Service

Copy to:

02 Multicuisine A-23, Block A&B, NN Towers, Community Centre, Road No.44, Pitampura, Delhi - 110034.

Following fire safety directives must be adhered to:

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with respect to construction shall be verified by the concerned building sanctioning agency.
5. The certificate cannot be treated in any case for regularizations of unauthorized Construction, if any
6. The number of seats shall not be increased to more than 98 seats as specified by the licensee.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs. Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in)



N-18

May kindly see letter of DHO dated 18/03/2016, In 2015 the owner increased the seats & FSC was renewed vide letter dated 20/03/2015. Now again the seat has been reduced to 98.

G+2 upper floor bag

INSPECTION REPORT

1. Name & address of the building: **O2 Multicuisine, A – 23, Block A & B, NN Towers, Community Center, Road No. 44, Pitampura, Delhi-110034.**
2. Type of Occupancy : **Assembly (G+1 Upper Floor)** ✓
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DMS/MS/EH/2013/194 Dated 23-04-2013**
5. Fire Safety directives Letter No. :
6. Date of inspection : **13-04-2016**
7. Name of the Inspecting Officer : **DO/W & ADO (WP)**
8. Name and designation of Officer
from the building side : **Sh. M.S. Rana (Manager)**
9. Year of Construction : **2005**
10. Applicant's letter No. : **Nil dated Nil**

Sr. No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6mtr	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Old case	1x1.48m1x0.97m	MR (Being Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old case	UF=1x83cm & 1x92cm GF=108cm & 83cm	MR (Being Old case)

3	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hr	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hr	Required	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	06	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC / CO2	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	1	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided	MR
		36 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	Provided	NA
		NA	NA	NA
		5000ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

N/2B-

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. **F6/DMS/MS/EH/2013/194 Dated 23-04-2013** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Officer


Name

Uday Vir Singh

Designation

ADo/OP

Signature of the Inspecting




Name

Sumil Chaudhary

Designation

Do/OP

Dy. C.F.O.

Director

 28/4

46/DCHA/2013
 28/4/16.