

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2016/SZ/ 651

Dated: 27/04/16

FIRE SAFETY CERTIFICATE

Certified that the United Catering Services (A unit of Divya Restaurants & Hotels Pvt. Ltd.) Located at B-93, Mayapuri, Phase-1, New Delhi, comprised of basement, ground plus three upper floors was issued NOC vide this department letter no. F6/DFS/MS/EH/2012/2638 dated 20.7.2012 for basement & ground floor only. The building was re-inspected by the officer concerned of fire service on 9.4.2016 in presence of Sh. Pawan Kumar (Account.) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the building is fit for occupancy class G "Industrial Building" sub Division-2 with effect from 27/04/16 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to compliance of the conditions printed overleaf.

Issued on 27/04/16 at New Delhi by


(Atul Garg)

Dy. Chief Fire Officer

Ph.011-26189168

Copy to:

- 1 Director, United Catering Services (A unit of Divya Restaurant & Hotels Pvt. Ltd.) 29, Central Market, West Punjabi Bagh, New Delhi-26.
- 2 The Deputy Health Officer, SDMC West Zone, New Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	United Catering Services (A Unit of Divya Restaurants & Hotels Pvt. Ltd.) B-93, Mayapuri, Phase-1, New Delhi.	
2	Type of Occupancy	Industrial Group G (Sub Div.2)	
3	Type of case	Renewal	
4	Details of previous NOC	F6/DFS/MS/EH/2012/2638 dated 20.7.2012	
5	Fire safety directives letter No	-	
6	Date of inspection	8.4.2016	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Sh.Pawan Kumar (Account)	
9	Year of construction	Before 2005	
10	Applicant's letter No.	Nil dated 28.3.2016	Buildg. Comprised of Basement, Ground + three upper floors Renewal of FSC under consi. For Basement & Ground Floor

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Accessible	18 Mtrs.	MR ✓
	2) Gate width	Approachable	3 Meters.	MR ✓
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Two	Two	MR ✓
	2. basements	Two	Two	MR ✓
	b. Width of staircase			
	1. Upper floors	125,75 Cms.	125,75 Cms.	MR ✓
	2. basements	200,90 Cms.	200,90 Cms.	MR (Kitchen only at ground floor) ✓
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR ✓
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Two	Two	MR ✓
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	-	2 Mtrs.	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR ✓
	2. Sealing of electrical shafts	Required	Sealed	MR ✓
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 ac charge	Exhaust Fan Provided	MR ✓
	Ground Floor	12 ac charge	Exhaust Fan Provided	MR ✓
	upper floors		N/A	N/A
5	Fire Extinguishers			
	total numbers	4 Nos. each floor	4 Nos. each floor	MR ✓
	Types	ABC	ABC	MR ✓
	ISI marking	ISI	Provided	MR ✓

6	First-Aid Hose Reels.			
	total numbers on each floor	1 No.	1 No.	MR ✓
	Length of Hose reel hose	30 m	30 m	MR ✓
	Nozzle Diameter	5 mm	5 mm	MR ✓
7	Automatic fire detection and alarming system			
	Type of detectors	Required	Provided	MR ✓
	location of Main Panel	-	Main gate	MR ✓
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	DG Set 62.5 KVA	MR ✓
	hooter's location	-	-	-
8	MOEFA	Required	Provided	MR ✓
9	Public Address System.	Required	Provided	MR ✓
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR ✓
	upper floors	Ground floor	Provided	MR ✓
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	900 LPM	900,220 LPM	MR ✓
	b. head of the pump	30 m	30 m	MR ✓
	c. Power supply	Required	Provided	MR ✓
	d. Auto starting of pump	Required	Provided	MR ✓
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	Provided	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	10000 Ltrs.	10000 Ltrs.	MR ✓
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	Provided	MR
	d. Fireman's grounding switch	N/A	N/A	Old lift
	e. Lift signage	Required	Provided	MR ✓

N/12

17	Standby power supply	Required	Provided	MR ✓
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	Required	Provided	N/A
	e. Building floor plans	N/A	N/A	MR
20	Special Fire Protection systems for protection of special risks, if any:		ABC	N/A

The fire protection systems provided in the building were checked/tested and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures required under the rules, renewal of fire safety certificate under rule 37 of the Delhi Fire Certificate is recommended.

Accordingly DFA is put up for approval and signature please.

Sury
12/4/16

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)

~~D/S~~

~~13/4/16~~

Dy CFCO (S2)

[Signature]
19/4/16

~~DIRECTOR/DAS~~

previous NOC was for
Basement + Ground only.
Now renewal is done for
Basement + Ground + Substructure
Explain the reasons.

~~Dy CFCO (S2)~~

EXR JWS NOC is
also for Basement + G floor only.

[Signature]
19/4