

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- director.dlfire@nic.in
No.F.6/DFS/MS/School/2016/SZ/655

Fax: - 011-23412593

Dated: 27/4/16

FIRE SAFETY CERTIFICATE

Certified that the building of **West Point Model School**, 12, Om Vihar Phase-II, Uttam Nagar, New Delhi-110059, comprised of ground floor plus three upper floors, was issued FSC by this department vide letter no. F6/DFS/MS/School/2013/55 dated 04.01.2013. The School building was re-inspected by the officer concerned of this department on 04.4.2016 in the presence of Sh. Rajesh Tandon (Manager) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....27/4/16..... at New Delhi.

DIRECTOR
DELHI FIRE SERVICE

DCS
27/4/16

Copy to:-

1. The Manager,
West Point Model School, 12, Om Vihar Phase-II,
Uttam Nagar, New Delhi-110059
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

School building is comprised of ground plus three upper floors.
(West Point Model School, 12, Om Vihar Phase-II, Uttam Nagar, New Delhi-110059)

INSPECTION REPORT

1. Name & address of the building : West Point Model School, 12, Om Vihar Phase-II, Uttam Nagar, New Delhi-110059.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/School/2013/55 dated 04.01.2013
5. Fire Safety directives letter No : N/A
6. Date of inspection : 04.4.2016
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Rajesh Tandon (Manager)
9. Year of Construction : 1995-96 (G+I) & 2011-12 (G+II & G+III)
10. Applicant's letter No. : Form 'J' dated 16.3.2016.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>—</p> <p>—</p>	<p>06 mtrs 4.8 & 03 mtrs</p> <p>—</p>	<p>M/R, being old case</p> <p>M/R</p> <p>—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basement 	<p>02 No's</p> <p>N/A</p>	<p>02 No's</p> <p>N/A</p>	<p>M/R</p> <p>No Basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>150 cms</p> <p>N/A</p>	<p>160 cms & 92 cms</p> <p>N/A</p>	<p>M/R (02 s.case)</p> <p>No Basement</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>
	d. No. of continuous staircases to terrace			
		N/A	One	N/A
	e. Width of Corridor	150 cms	186 cms	M/R
	f. Door Size	—	90 cms	M/R (being old case)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	No Basement

SAN

School building is comprised of ground plus three upper floors.
(West Point Model School, 12, Om Vihar Phase-II, Uttam Nagar, New Delhi-110059)

	<ul style="list-style-type: none"> Upper floors 	—	Natural ventilation	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	14 no's	Provided	M/R ✓
	<ul style="list-style-type: none"> Types 	ABC/CO ₂ type	Provided	M/R ✓
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	M/R ✓
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	One	Provided	M/R ✓
	<ul style="list-style-type: none"> Length of hose reel hose 	30 mtrs	Provided	M/R ✓
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	M/R ✓
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8.	MOEFA			
		N/A	N/A	N/A
9.	Public Address System			
		N/A	Provided	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/A	Provided	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	One	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	One	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A

Saha

School building is comprised of ground plus three upper floors.
(West Point Model School, 12, Om Vihar Phase-II, Uttam Nagar, New Delhi-110059)

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		450 LPM	Provided	M/R ✓
		30 mtrs	Provided	M/R ✓
		Required	Provided	M/R ✓
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	N/A	N/A
		10,000 ltrs	Provided	M/R ✓
		Required	Provided	M/R ✓
15.	Exit Signage.			
16.	Provision of Lifts.			(No Lift)
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

Saw

School building is comprised of ground plus three upper floors.
(West Point Model School, 12, Om Vihar Phase-II, Uttam Nagar, New Delhi-110059)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F6/DFS/MS/School/2013/55 dated 04.01.2013 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Sandeep
12/4/16

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation

D.O. (South West)

R. Kumar
18/4/16

Dy CFO (S2)

19/4/16

DIRECTOR

21/4

MS

A.T. letter is put up for signature please.

Director

22/4

Sandeep
22/4/16