

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/2016/SZ/728

Dated: 09/05/16

FIRE SAFETY CERTIFICATE

Certified that the M/S International Youth Hostel Building, located at No.5, Nyaya Marg, Chanakyapuri, New Delhi-110021, comprised of basement, ground plus three upper floors having 39 guest rooms only, owned/occupied by National Youth Hostel Trust was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/GH/2013/318, dated 20-05-13. The premises was re-inspected by the officer concerned of this department on 03-05-2016 in the presence of Sh. Satish Kumar (Care Taker of Hostel) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class A "Residential Lodging or Rooming House" with effect from 09/05/2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/05/2016 at New Delhi by.

  
(Atul Garg)

Dy. Chief Fire Officer

T.No.011-26189168

Copy to:- Sh. Yudhisthir Sharma, Secretary, International Youth Hostel, No.5, Nyaya Marg, Chanakyapuri, New Delhi-110021.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building : M/S International Youth Hostel, No.5, Nyaya Marg, Chanakyapuri, New Delhi-110021.
2. Building comprised of : B+G+3Upper floors.
3. Type of Occupancy : Group "A" Residential Lodging or Rooming House.
4. Type of Case : Renewal.
5. Details of Previous NOC : No.F6/DFS/MS/GH/2013/318, dated 20.05.13.
6. Fire Safety direction letter No : NIL.
7. Date of Inspection : 03.05.16.
8. Name of the Inspecting Officers: : Vedpal (ADO).
9. Name and designation of Officer from the building side : Sh. Satish Kumar, (Care Taker of Hostel).
10. Year of Construction : 1976.
11. Applicant's letter No : No.Nil, dated 20.04.16.

S.No	Minimum Standards on fire prevention and fire safety as per Rule 33.	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	10m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases Upper Floor	2nos.	2nos. upto 2 <sup>nd</sup> floor & 1no. upto 3 <sup>rd</sup> floor	MR(old case)
	Basement	02nos	02nos.	MR
	B. Width of Staircases Upper Floor	1.25m/1m	1.5m & 1m	MR
	Basement	1.25m/1m	1.5m & 1m	MR
	c. Protection of exits Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1no.	1no.	MR
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	1mtr.	1mtr.	MR
	3	Compartmentation		
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	Exhaust fan Provided	MR
	Upper floor	15 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguisher			
	Total numbers	20 nos.	36 nos.	MR
	Types	ABC&WCO <sub>2</sub>	ABC&WCO <sub>2</sub>	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	02nos.	02nos.	MR.
	Length of hose reel hose	30m	30m	MR.
	Nozzle diameter	5cm	5cm	MR.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power			

10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	150mm	150mm	MR
	Number of hydrants per floor	02nos.	02nos.	MR
	Hose Box	02nos.	02nos.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	1500LPM	1500LPM	MR.
	➤ Head of Main Pump	40m	40m	MR
	➤ Number of main pumps	01no.	01no.	MR
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Pump House Access	Required	Provided	MR
	➤ Terrace Level	450LPM	450 LPM	MR
	➤ Discharge of pump	35m	35m	MR
	➤ Head of the Pump	Required	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	5000Liters	50000Liters	MR
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	10000Liters	10000Liters	MR
15	Exit Signage.	Required	Provided	M R
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	Required	Provided	M R
	Firemen's grounding switch	Required	Provided	M R
	Lift Signage	Required	Provided	M R
17	Standby power supply	Required	Provided ( DG Set)	M R
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Battery backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.


Nr 36

M/S International Youth Hostel, No.5, Nyaya Marg, Chanakyapuri, New Delhi-21.

20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.
----	--	------	------	------

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the Fire Safety Certificate issued vide letter No.F.6/DFS/MS/GH/2013/318, dated 20.05.13, renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.


Accordingly DFA is put up for kind consideration please.

 4/5/16

Signature of the Inspecting Officer


Name Vedpal

Designation ADO

 5/5/16

Dy.CFO.(D.P.B.)

~~Dy.C.F.O. (South Zone)~~

  
6/5/16

~~DIRECTOR/DPS~~

  
6/5