

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

NO.F6/DFS/MS/School/2016/SZ/ 714

Dated: 06/05/16

FIRE SAFETY CERTIFICATE

Certified that the Kenderiya Vidhalaya located at Sector-8, SPG Complex, Dwarka New Delhi-110077, comprised of ground plus three upper floors was granted NOC by this department vide letter no. F6/DFS/MS/School/2012/1624 dated 04.05.2012. The building was re-inspected by the officer concerned of this department on 28.4.2016 in presence of Smt.Sunita Rai principal of the school & found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class B "Educational building" with effect from..06/05/16.. for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on06/05/16..... at New Delhi by


(Atul Garg)

Dy. Chief Fire Officer
Ph.011-26189168

Copy to:

1. Principal, Kenderiya Vidhalaya, Sector-8, SPG Complex, Dwarka New Delhi-110077.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

	Name & address of the building	Kendriya Vidhalaya , Sector-8, SPG Complex Dwarka, New Delhi-110077.	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal	
4	Details of previous NOC	F6/DFS/MS/School/2012/1624 Dated 04.5.2012	
5	Fire safety directives letter No	As per NBC Part IV	
6	Date of inspection	28.04.2016	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Mrs. Sunita Rai Principal	
9	Year of construction	2010-11	
10	Applicant's letter No.	F.No.2-29/KVSPG/2015-16/1886 dated 17.03.2016	ground plus three upper floors

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Accessible	9 Mtrs.	MR
	2) Gate width	Accessible	5 Mtrs.	M/R
	3) Width of internal road	N/A	6 Mtrs.	MR
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	3 Nos.	3 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	1.58,1.50,1.47 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	ONE	ONE	MR
	e. Width of corridor	2.35 Mtrs.	2.35 Mtrs.	MR
	f. Door size	.90 Mtr.	.90 Mtr.	MR being old case
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	Sealed	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		N/A	N/A
5	Fire Extinguishers			
	total numbers	4 at each floor ABC	16 Nos.	MR
	Types	ISI Marked	ABC	MR
	ISI marking		ISI Marked	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	Two	Two	MR
	Length of Hose reel hose	30 m	30 m	MR
	Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	100 mm	MR
	Number of Hydrants per floor	N/A	Two	MR
	hose Box	N/A	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	Two	MR
	hose box	N/A	Two	M/R
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	2 Pumps 450 LPM	MR
	b. head of the pump	30 M	38 M	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	10000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/110

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plans	N/A	Provided	N/A
20	Special Fire Protection systems for protection of special risks, if any:	ABC		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate is recommended under rules 37 of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
 Signature of the Inspecting Officer
 28/4/16

Name S.P. Bhardwaj

Design. ADO (Dwarka)

~~DASW~~

K. Kumar
 28/4/16

Dy (FOCS) *[Signature]*
 29/4/16

DIRECTOR *[Signature]*