

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/2016/ W 2/742

Dated: 10/05/16

FIRE SAFETY CERTIFICATE

Certified that the **Aggarwal Corporate Height**, located at **A-7, Netaji Subhash Place, Wazir Pur District Centre, Delhi - 110034** comprised of Basement + Ground + 15 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2013/169 dated 10-04-2013. The premises was re inspected by the officers concerned of this department on 28-04-2016 in the presence of Mr. Sunil Jain (Vice President) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Mercantile & Business Building" Group F & Group E with effect from 10/05/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....10/05/16... at New Delhi by.



Director

Delhi Fire Service.

Copy to:

1. Sh. Sunil Jain (Vice President), A-7, Netaji Subhash Place, Wazir Pur District Centre, Delhi - 110034 Following fire safety directives must be adhered to:-
1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
  2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
  3. The trained staff should be available round the clock.
  4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
  5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
  6. Basement shall be used as per building bye laws.
  7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building: Aggarwal Corporate Height, A-7, Netaji Subhash Place, Wazir Pur District Centre, Delhi – 110034.
2. Type of Occupancy : Mercantile + Business (Mixed), (Basement + Ground + 15 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2013/169 dated 10-04-2013
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2007/663 dated 06-03-07
6. Date of inspection : 28-04-2016
7. Name of the Inspecting Officer : DO (West) & ADO (WP)
8. Name and designation of Officer  
from the building side : Sh. Sunil Jain (Vice President)
9. Year of Construction : 2008-09
10. Applicant's letter No. : Form J dated 15-04-2016

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 m	Provided	MR
	• Gate width	5 m	On open Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	2x125cm	1x140cm & 1x150cm	MR
	• Basements	2x125cm	1x129cm & 135cm	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	150cm	Provided	MR
	f. Door Size	1m	Provided	MR

23.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	Exhaust Fans Provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	NA	NA	NA(Build. Not centralized AC)
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	37 nos. CO <sub>2</sub> & ABC ISI marked	Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>		Provided	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>		Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	1	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	Smoke & Heat	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	150 mm	Provided	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	1	Provided	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	NA	Provided	NA
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	NA	Provided	NA

13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	2850 lpm	Provided	MR
		80 m	Provided	MR
		2	Provided	MR
		2x180 lpm	Provided	MR
		80 m	Provided	MR
		2850 lpm	Provided	MR
		80m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw of connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	2,00,000 litres	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20, 000 litres	Provided	MR
		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts( Lift Run from GF to 15 <sup>th</sup> Fs)			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply			
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	Required	Provided	MR
		5 <sup>th</sup> , 7 <sup>th</sup> , 10 <sup>th</sup> Floor	Provided	MR
19.	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

20.	Special Fire Protection Systems for Protection of special Risks, if any;	Manual CO2	Provided	MR
-----	--	------------	----------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/DFS/MS/2013/169 dated 10-04-2013 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Vir Singh

Name

Somil Chaudhary

Designation

ADo/WP

Designation

Do/W