

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

E-mail: gargatul@hotmail.com, Tel:- 011-26189168

NO.F6/DFS/MS/2016/ 52/739

Dated 10/05/16

FIRE SAFETY CERTIFICATE

Certified that M/s. Auto Grit, A Petroleum Retail Outlet of Bharat Petroleum Corporation Ltd., located at Lal Kuan, M.B. Road, New Delhi-110044 was inspected by the officer concerned of this department on 22-04-2016 in presence of Mr. Prem Prakash Sharma, Partner and found that the said fuel station have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service Rules 2010, and that the building/premises is fit for occupancy **Class J (Hazardous)** with effect from 10/05/16 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/05/16 at New Delhi by.


(ATUL GARG)
Dy. Chief Fire Officer

Copy to: -

1. The Manager, M/s. Auto Grit, A Petroleum Retail Outlet of Bharat Petroleum Corporation Ltd., Kuan, M.B. Road, New Delhi-110044.
2. The Joint C.P.(Lic.), Police Station, Defence Colony, 1st floor, New Delhi..

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time.
- b. Loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- c. The trained fire fighting staff should be available round the clock.
- d. Good house keeping shall be ensured.
- e. Nothing contravention of the Explosive act-1984 & Rules their under 1983 and static & mobile pressure vessels (unfired) Rules-1981 as modified up to date and the comments of Chief Controller of Explosive should be permitted/followed.
- f. No trade susceptible to cause ignition to Patrol/Diesel by generating heat, mechanical/electrical spark, shall be allowed within the licensed premises.
- g. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s. Auto Grit, A Petroleum Retail Outlet of Bharat Petroleum Corporation Ltd., Lal Kuan, M.B. Road, New Delhi-110044
2. Type of Occupancy : Hazardous (Class - J)
3. Type of Case : New Case
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : Delhi Fire Service Act-2007 & Delhi Fire Service Rules- 2010
6. Date of inspection : 22.04.2016
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(M.Rd)
8. Name and designation of officers from the building side : Mr. Prem Prakash Sharma, Partner
9. Year of Construction : 2014-15
10. Applicant's letter No. : nil dated 05.04.2016

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	-----	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	---	---	---
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	---	---	---
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	---	---	---
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	N/A	N/A	N/A
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A

	<ul style="list-style-type: none"> Total numbers Types IS marking 	21 CO ₂ , DCP ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	----- 45 m	N/A	N/A
	<ul style="list-style-type: none"> Length of hose reel hose 	5 mm	N/A	N/A
	<ul style="list-style-type: none"> Nozzle diameter 		N/A	N/A
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8	MOEFA			
9	Public Address System.			
		N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 	-	-	-
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	N/A	N/A	N/A
		N/A	N/A	N/A

	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Provided	MR

The fire protection systems such as "No Smoking" sign board, fire extinguishers, sand buckets etc. provided in the building were tested / checked and found functional at the time of inspection.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant fire safety certificate under Delhi Fire Service Act- 2007 & Delhi Fire Service Rules- 2010.

Accordingly DFA is put up for signature please.

DCFO (Dharampal Bhardwaj)

6/5/16

M.K.CHATTOPADHYAY
Asstt. Div. Officer (M.Road)