

FORM- H]
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.

F6/DFS/MS/school/2016/w2/773

Dated:

13/05/16

FIRE SAFETY CERTIFICATE

1. Certified that the **Nigam Pratibha Vidyalaya School** Located at **B.B, Block Shalimar Bagh Delhi- 110088**. Comprised of Two Block of Ground + 1 Upper Floor & Ground floor Only was issued FSC vide Letter No. F6/DFS//MS/SCHOOL/2013/189 Dated – 18/04/2013. The premises was re inspected by the officer concerned of this department on **22-04-2016** in the presence of Smt. Neelam Seth (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01/03/2011 and that the premises is fit for occupancy class “Educational” Group B with effect from 13/05/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on13/05/16..... at New Delhi by.

(Dr. G.C. Mishra)
Director
Delhi Fire Service

Copy to:

1. The Principal,
Nigam Pratibha Vidyalaya School B.B, Block Shalimar Bagh Delhi- 110088.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. All the exit must be kept free from any obstruction and open all the time.

INSPECTION REPORT

2. Name & address of the building: **Nigam Pratibha Vidyalaya School** Located at **B.B, Block Shalimar Bagh Delhi- 110088.**
3. Type of Occupancy : Educational Block – 2, One Block (Ground + 1 Upper Floor) & Second Block (Ground Only)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS//MS/SCHOOL/2013/189 Dated – 18/04/2013
6. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
7. Date of inspection : 22/04/2016
8. Name of the Inspecting Officer : Udai vir singh, ADO (WP)
9. Name and designation of Officer
from the building side : Smt. Neelam Seth (Principal)
10. Year of Construction : 1983
11. Applicant's letter No. : Nil dated 02/04/2016

No. of Students= 886+92

No. of class rooms= 23

Plot area= 6400 sqm

Covered area= 2900 sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtr	Provided	MR
		Old Case	350 cm	MR(Being old case)
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150cm	1X138 cm & 1x131cm	MR
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door			
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	01	Provided	MR
	f. Door Size	1.5 mtr	1.9 mtr	MR
		1 mtr	96cm	MR(Being old case)

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	10 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> • Nozzle diameter 	NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

13	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
➤ Auto starting of pump	NA	NA	NA	
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

N/9

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

- 1. Escape routeClear.....
- 2. LPG cylinders in laboratories ; NA
- 3. Electric wiring ...Conduit Wiring..... MCB and ELCB
Electric circuit
- 4. Electric meter board under the staircase in the room
- 5. Basement use as per BBL 1983 ... NA
- 6. Emergency telephone no. boardDisplayed...
- 7. Generator set NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS//MS/SCHOOL/2013/189 Dated – 18/04/2013 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer ~~26/4/16~~

Signature of the Inspecting Officer

Name Uday Vir Singh

Name

Designation AD O/W P

Designation

AD O/W P
26/4

Dy. C.O.
Director
beent
4/5
5/5

57/Dfo Cas
5/5/16