

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110 001

No. F.6/DFS/MS/GH/2016/ND2/752

Dated: 11/05/16

FIRE SAFETY CERTIFICATE

Certified that the Guest House **Rama Deluxe** located at **2278-79, Chowk Gurudwara Road, Karol Bagh, New Delhi-110005** comprises of Ground floor, Mezzanine + Three Upper floors, using Ground floor as reception and office, mezzanine floor as hall for office purpose, first and second floor each having nine guest rooms respectively, third floor having seven guest rooms and one office (**Total 25 guest rooms**), a staff pantry with staff room and D.G set on terrace was granted NOC by this department vide letter No.F.6/DFS/MS/GH/2013/204 dated 25-04-2013. The premises was re-inspected by the officer concerned of this department on 06-05-2016 in the presence of Sh. Manoj Singh and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub-Division A-1 Guest House** for 25 guest rooms with effect from ~~11/05/16~~ 11/05/16 2016 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....11/05/16.....at New Delhi by.

(Rajesh Panwar)  
Dy. Chief Fire Officer  
Ph:-011-23412025

Copy to:-

1. The Joint Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049 w.r.t. letter No. 972/Joint C.P./Lic.(H) dated New Delhi 28-04-2016
2. Sh. Sukhpal Singh (Owner), Guest House Rama Deluxe, 2278-79, Chowk Gurudwara Road, Karol Bagh, New Delhi-110005.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction, etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

### INSPECTION REPORT

1. Name & address of the building : G.H Rama Deluxe, 2278-79, Chowk Gurudwara Road, Karol Bagh, New Delhi-110005.
2. Type of Occupancy : Residential (G.H ) G+Mezz+3 Floor total guest rooms-25
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/GH/2013/204 dated 25/04/2013
5. Fire Safety directives letter No : N/A
6. Date of inspection : 06/05/2016
7. Name of Inspecting Officer : Dy. C.F.O Rajesh Panwar
8. Name and designation of officers  
From the building side : Sh. Manoj Singh
9. Year of Construction : Before 1990
10. Applicant's letter No. : 972/Joint C.P/Lic.(H) dated 28.04.2016


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible NA NA	12 mtr NA NA	MR NA NA
<b>2.</b>	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	One	One	MR, Old Case
	• Basements	NA	NA	No Basement
	b. Width of staircases			
	• Upper Floor	125 cms	90cm to 94 cms	MR, Old Case
	• Basements	NA	NA	No Basement
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	One	One	MR
	e. Width of Corridor	1.0 Mtr	3.0 Mtr	MR
	f. Door Size	1.0 Mtr.	87 cm X 205 cm	MR, Old Case
<b>3.</b>	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	Sealed	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
<b>4.</b>	<b>Smoke Management System</b>			
	• Basements	30 ACPH	NA	No Basement
	• Upper floors	12 ACPH	Natural Ventilation	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	• Total numbers	02 at each floor	Provided	MR
	• Types	Co2, WCO2	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
<b>6.</b>	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	• Basement	NA	NA	No Basement
		NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling			
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	30 M	30 M	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	NA	NA	NA
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2500 Ltr	2500 Ltr	MR, Old Case
		Required	Provided	MR
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	Old Lift
	• Lift Signage	Required	Provided	MR

17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	NA	NA	NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/GH/2013/204 dated 25.04.2013 renewal under rule 35 of Delhi Fire Service Rules 2010, is recommended please.

Signature of Inspecting Officer 


Name:- Rajesh Panwar

Designation:- Dy. C.F.O (NDZ)

Signature of Inspecting Officer

Name

Designation

  
Director  
11/5