

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- director.dlfire@nic.in

No.F.6/DFS/MS/School/2016/ 52/ 769

Fax: - 011-23412593

Dated: 13/5/16

FIRE SAFETY CERTIFICATE

Certified that the building of **St. Mark's Sr. Sec. Public School**, Janak Puri Marg, Janak Puri, New Delhi-110058, is comprised of ground floor plus two upper floors, was issued Fire Safety Certificate by this department vide letter F6/DFS/MS/School/2013/77 dated 15.03.2013. The School building was re-inspected by the officer concerned of this department on 06.5.2016 in the presence of Smt. Rama Sethi (Principal) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on..... 13/5/16..... at New Delhi.

[Handwritten signature]
13/5

DIRECTOR
DELHI FIRE SERVICE

[Handwritten initials]
12/5/16

Copy to:-

1. The Chairman,
St. Mark's Sr. Sec. Public School,
Janak Puri Marg, Janak Puri, New Delhi-110058.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : St. Mark's Sr. Sec. Public School, Janak Puri Marg, Janak Puri, New Delhi-110058
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/School/2013/77 dated 15.03.2013
5. Fire Safety directives letter No : N/A
6. Date of inspection : 06.5.2016
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Smt. Rama Sethi (Principal)
9. Year of Construction : Before 2006
10. Applicant's letter No. : Nil dated 25.4.2016.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>—</p> <p>—</p>	<p>12 mtrs</p> <p>4.5 & 3.5 mtrs</p> <p>—</p>	<p>M/R</p> <p>M/R</p> <p>—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>06 No's</p> <p>N/A</p>	<p>06 No's</p> <p>N/A</p>	<p>M/R</p> <p>No basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>—</p>	<p>153, 170, 150, 115, 110, (105 cms GF to FF)</p>	<p>M/R, being old case</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>	<p>No basement</p> <p>N/A</p>
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	One	N/A
	f. Door Size	150 cms	225, 240, 180 & 150 cms	M/R
		100 cms	100 & 114 cms	M/R, being old case
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	No basement

Saw

2/8

Ground plus two upper floors
(St. Mark's Sr. Sec. Public School, Janak Puri Marg, Janak Puri, New Delhi-110058)

	<ul style="list-style-type: none"> Upper floors 	—	Natural ventilation	M/R ✓
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 no's ABC/CO ₂ type ISI marked	30 no's Provided Provided ISI marked	M/R ✓ M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Two 30 mtrs 5 mm	Provided Provided Provided	M/R ✓ M/R M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	75 mm one one	N/A N/A N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	one one	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A

Saw

2/9

Ground plus two upper floors
(St. Mark's Sr. Sec. Public School, Janak Puri Marg, Janak Puri, New Delhi-110058)

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		450 LPM	450 LPM & 180 LPM	M/R
		30 mtrs	Provided	M/R
		Required	Provided	M/R
		N/A	Provided	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
			4000 ltrs	M/R, being old case
		Required	Provided	M/R
15.	Exit Signage.			
16.	Provision of Lifts.			(No Lift)
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply			
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

San

2/10

Ground plus two upper floors
(St. Mark's Sr. Sec. Public School, Janak Puri Marg, Janak Puri, New Delhi-110058)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F6/DFS/MS/School/2013/77 dated 15.03.2013 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

~~Sandeep
09/5/16~~

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

~~Signature of Inspecting Officer~~

~~Name~~

~~Designation~~

D.O. (South West)

~~Dy CFO (S2)~~

~~Kishor
10/5/16~~

~~10/5/16~~