

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001

E-mail: [gargatul@hotmail.com](mailto:gargatul@hotmail.com), Tel:- 011-26189168

No. F6/DFS/MS/School/2016/52/790

Dated: 17/5/16

**FIRE SAFETY CERTIFICATE**

Certified that **Lions Vidhya Mandir Secondary School located at Kushak Lane, New Delhi** comprised of ground plus two upper floors was granted fire safety certificate by this department vide letter No. F.6/DFS/MS/School/2013/287 dated 10-05-2013. The school building was re-inspected by the officer concerned of this department on 07/05/2016 in presence of Mr. Pradeep Kumar, Vice Principal of the school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. F.6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of 03 (three) years, subject to compliance of the under mentioned conditions.

Issued on 17/5/16 at New Delhi by.

(ATUL GARG)

Dy. CHIEF FIRE OFFICER

Copy to: -

1. The Principal, Lions Vidhya Mandir Secondary School, Kushak Lane, New Delhi
2. The Director of Education, MCD (North), Kashmere Gate, Nigam Bhawan, Delhi

**Conditions for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building : Lion's Vidya Mandir Secondary School, Kushak Lane, New Delhi-1
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2013/287 dated 10-05-2013
5. Fire Safety directives letter No : F.16/ESTATE/CC/Fire Safety/2011/3298-3398 dated 01.03.2011
6. Date of inspection : 07.05.2016
7. Name of the Inspecting Officers : M.K. Chattopadhyay, ADO (MRD)
8. Name and designation of officers  
from the building side : Shri Pradeep Kumar, Vice Principal
9. Year of Construction : 1960
10. Applicant's letter No. : VM/Fire Safety/2016/6921 dated 25-04-2016

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	11 mts	MR
	• Gate width	03 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	04	5 stair + 01 ramp	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	1.5 mts	1.60(2), 1.20 (2), 1.08(1), Ramp- 1.22 mts	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits .			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	02	01 stair + 01 ramp	MR
	h. Door Size	N/A	N/A	N/A
		N/A	N/A	N/A
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System. Low-rise bldg, Not required</b>			

	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	N/A N/A	N/A N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	12 ABC, CO <sub>2</sub> ISI marked	Provided Provided Provided	MR MR MR
6	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7	<b>Automatic fire detection and alarming system. Not required</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm 01 01	Provided Provided Provided	MR MR MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A N/A	N/A N/A	N/A N/A
13	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> </ul>	N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A

	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 LPM (2)	Provided	MR
		40 meters	Provided	MR
		N/A	N/A	N/A
		-	Provided at GF	MR
14	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 liters	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>	<b>Not Applicable</b>		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	01 ABC type fire extinguisher provided	MR

The fire protection systems provided in the building were tested / checked and found functional at

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules; the NOC issued vide letter No. F.6/DFS/MS/School/2013/287 dated 10-05-2013, renewal under the Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 is recommended.

DFA is put up for approval & signature please

~~DCFO (D. P. Bhardwaj)~~


-----  
DCFO (SZ)

~~13/5/16~~

~~DIRECTOR / OFS~~

~~18/5~~

~~11/5/16~~

  
10/5/2016

Signature of the Inspecting Officer  
(M.K. CHATTOPADHYAY)  
Assistant Divisional Officer (MRD)