

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No. F6/DFS/MS/EH/2016/829

Dated - 20/05/16

FIRE SAFETY CERTIFICATE

Certified that the Pind Balluchi Restaurant running at basement, ground plus two upper floor at 410, Karkardooma Village, Delhi-96, comprised of basement, ground plus four upper floors owned/occupied by M/s(A unit of M/s Royal Cuisine was granted FSC vide letter No. F6/DFS/MS/EH/2013/205 dated 11.01.13. The Premises was re-inspected by the officer concerned of this department on 25.04.2016 in the presence of Mr. Devender Thapa (Manager) and found that the restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and found that the B+GF+FF+SF of building is fit for occupancy class "Eating House (Restaurant)" with effect from 20/05/16..... for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on 20/05/16..... at New Delhi by



(Rajesh Panwar)
Dy. Chief Fire Officer
Ph- 011- 23412025

To

Pind Balluchi Restaurant.
(A unit of M/s Royal Cuisine)
410, Karkardooma Village, Delhi-96

Copy to-

The Deputy Health Officer,
Shahdara (South) Zone, EDMC,
Health Department, Shahdara South Zone, Karkardooma, Delhi

o/c
15

Conditions

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This FSC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used as per BBL
8. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

- N/13
1. Name & address of the building : M/s Pind Balluchi Restaurant running at B,G+2 upper floor (A unit of M/s Royal Cuisine 410, Karkardooma Village, Delhi-96
 2. Building is comprised of : basement, ground plus four upper floors(4th floor temporary)
 3. Type of Occupancy : Assembly
 4. Type of Case : Renewal
 5. Details of Previous FSC : F6/DFS/MS/EH/2013/205 Dated 11.01.2013
 6. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010.
 7. Date of Inspection : 25.04.2016
 8. Name of the Inspecting Officers: : R.K.Yadav ADO(LN)
 9. Name of the designation of Officer from the building side : Mr.Devender Thapa (Manager)
 10. Year of Construction : 2000
 - 11.Applicant's letter No : Nil Dated 6.04.2016

	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	06 m	24 m	MR
	Gate width	NA	NA	NA
	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 no.	2 no.	MR
	Basement	1 no.	1 no.	MR
	b. Width of Staircases			
	Upper Floor	2 m	1.2 m, 1.1 m	MR
	Basement	1.2 m	1.2 m	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	1 no.	1 no.	MR
g. Width of Corridor	NA	NA	NA	
h. Door Size	2 m	1m & 1.5 m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	Ventilated	Ventilated	MR
	• Upper floor	Ventilated	Ventilated	MR

W/14


5.	Fire Extinguisher			
	• Total numbers	10 no.	10 no.	MR
	• Types	CO ₂ + ABC	CO ₂ + ABC	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	01 no	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Heat	Provided	MR
	Location of main panel	NA	NA	NA
	Location of repeater panel	NA	NA	NA
	Alternate source of power	NA	Provided	MR
	Hooter's location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants per floor	1 no.	1 no	MR
	Hose Box	1 no.	1 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

N-15

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	5,000 Liters	5,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Firemen's grounding switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	Detector system panel	NA	NA	NA
	Flow switch panel	N/A	NA	NA
	PA system panel	N/A	NA	NA
	Batter backup	N/A	NA	NA
	Building Floor Plans	N/A	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The fire safety certificate issued vide letter no. F.6/DFS/MS/EH/2013/205 Dated 11.01.13 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name:-R.K.Yadav
 Designation:-ADO (LN)

DCFO (Virendra Singh)

Submitted for approval please.

Dumra/1000

Singh
 5/5/16