

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail : gargatul@hotmail.com

Ph. 011-26189168

No.F.6/DFS/MS/School/2016/ 52/848

Dated: 20/5/16

FIRE SAFETY CERTIFICATE

Certified that the building of **Sanskar Bharti Public School** located at 279, Street No-13, Than Singh Nagar, Anand Parbat, New Delhi-110005 is comprised of ground floor plus two upper floors but the school is running at first floor only owned/occupied by the school management was inspected by the officer concerned of this department on 16.05.2016 in the presence of Smt. Jyoti Aggarwal (Principal) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building (**at first floor only**) is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on.....20/5/16.....at New Delhi.


(ATUL GARG)

DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE


OK Saw
20/5/16

Copy to:-

1. The Principal,
Sanskar Bharti Public School, 279, Street No-13,
Than Singh Nagar, Anand Parbat, New Delhi-110005
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Sanskar Bharti Public School, 279, Street No-13, Than Singh, Nagar, Anand Parbat, New Delhi-110005.
2. Type of Occupancy : Educational (School)
3. Type of Case : Fresh
4. Details of Previous NOC : NA
5. Fire Safety directives letter No : NA
6. Date of inspection : 16.05.2016
7. Name of Inspecting Officer : A.D.O Sandeep Duggal
8. Name and designation of officers
From the building side : Smt. Jyoti Aggarwal (Principal)
9. Year of Construction : 1997
10. Applicant's letter No. : Nil dated 04.05.2016

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible NA NA	12 mtr 98 cms NA	MR ✓ NA NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	One/Two NA	Two NA	MR ✓ No Basement
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	150/75 cms (02) NA	100cm, 75 cms NA	MR ✓ No Basement
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	One	One	MR ✓
	e. Width of Corridor	---	100 cms	MR, Old Bldg. ✓
	f. Door Size	---	80 cms	MR, Old Bldg. Students less than 45 in each class ✓
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	12 ACPH 12 ACPH	NA Natural Ventilation	No Basement MR ✓
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	02 Nos ABC, Co2 ISI marked	Provided Provided ISI marked	MR ✓ MR ✓ MR ✓
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA 30 m 5 mm	NA NA NA	NA NA NA

7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	No Basement
		NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling			
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
		NA	NA	NA
15.	Exit Signage.			
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	No Lift
	• Pressurization of Lift lobby	NA	NA	-do-
	• Communication In lift Car	NA	NA	-do-
	• Fireman's Grounding Switch	NA	NA	-do-

Can

N/16

	• Lift Signage	NA	NA	-do-
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The building is comprised of ground floor plus two upper floors but the school is running at first floor only. The upper floors are served by two staircases having width 100 cms & 75 cms respectively.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire safety Certificate under rule 35 of the Delhi Fire Service rules 2010.

Sandeep
17/5/18

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation

D.O (South West)

KT...
17/5/18