

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Email:gargatul@hotmail.com, Tel:- 011-26189168



NO.F6/ DFS/MS/SZ/School/2016/ 837

Dated: 20/5/16

FIRE SAFETY CERTIFICATE

Certified that S.D.M.C. Primary School, located at Mandi Village, New Delhi-47, comprised of in two blocks- A-Block- ground floor only and B-Block- ground plus one upper floor owned/occupied by SDMC of Delhi was granted FSC by this department vide letter no. F6/DFS/MS/School/2012/667 dated 24/02/2012. The School building was re- inspected by the officer concerned of this department on 16/05/2016 in the presence of Mrs. Rajni Jain and found that the school building have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 issued by the Directorate of Education dated 01-03-2011 and that the school building is fit for occupancy class "Educational"(School) with effect from the date of issue ..20/5/16..... of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on..20/5/16.....at New Delhi by.


(ATUL GARG)
DY. CHIEF FIRE OFFICER (SZ)
7c 

Copy to: -

Mrs. Rajni Jain
S.D. M.C. Primary School,
Mandi Village, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

N/4

INSPECTION REPORT

1. Name & address of the building:-S.D.M.C Primary School, Mandi Village, New Delhi-47
2. Type of occupancy:- Educational (School)
3. Type of case: - Renewal
4. Details of previous NOC: - F6/DFS/MS/School/2012/667 Dated 24/02/12
5. Fire safety directives No.- F.16/Estate/CC/Fire/Safety/2011/3298to3398 dated 01/03/2011
6. Date of inspection:- 16/05/2016
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mrs. Rajni Jain
9. Year of construction:- 1999 & 2011
10. Applicant's letter No:- Nil dated 03/05/2016
11. Composition of building: - Building is in two blocks- A-Block- ground floor only and B Block- ground plus one upper floor.

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required	Approachable	MR
	2) Gate width	5mtr	Provided	MR
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01no	02nos	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.50m	1.50m each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01no	Provided	MR
	E. Width of corridor	1.5m	2.04m & 2m	MR
	F. Door size	1m	1m	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Open Corridor	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	08 Nos	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR

6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location			
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Underground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR

N/6

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

Keeping in view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Education Department vide Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01-03-2011, renewal of fire safety certificate issued vide letter no.F6/DFS/MS/School/2012/667 dated 24/02/2012 is recommended.

Accordingly DFA is put up for sign pl.

[Handwritten Signature]
17/5/2016

Signature of the inspecting officer

Name: - D.B.Mukherjee.

Designation:- Assistant Divisional Officer (BCP)

Dy C/O (D.P. Bhandari)

18/5/16