

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

E-mail: gargatul@hotmail.com, Tel:- 011-26189168

No. F6/DFS/MS/School/2016/52/805

Dated: 19/05/16

FIRE SAFETY CERTIFICATE

Certified that U.P. Project School located at Canal Colony, Okhla, New Delhi- 110025 was granted NOC by this department vide letter No. F.6/DFS/MS/2006/1919 dated 04.08.2006 for ground floor only. The school building was re-inspected by the officer concerned of this department on 10.05.2016 in presence of Mrs. Meera Singh, principal of the school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. 262-362 dated 17-01-2005 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the under mentioned conditions.


Issued on ~~19/05/16~~ at New Delhi by.


(ATUL GARG)

Dy. CHIEF FIRE OFFICER

Copy to: -

1. The Manager, U.P. Project School, Canal Colony, Okhla, New Delhi- 110025.
2. The Directorate of Education, Old Secretariat, GNCT of Delhi, New Delhi-110006.

9c 
19/5/2016

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : U.P. Project School, Canal Colony, Okhla, New Delhi- 110025
1. Type of Occupancy : Educational
2. Type of Case : renewal
3. Details of previous NOC : F.6/DFS/MS/2006/1919 dated 04.08.2006 for ground floor only
4. Fire Safety directives letter No : 262-362 dated 17-12-2005
5. Date of inspection : 10.05.2016
6. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(M.Rd)
7. Name and designation of officers
from the building side : Mrs. Meera Singh, principal
9. Year of Construction : 2006
10. Applicant's letter No. : nil dated 04.05.2016

U.P. Project School is comprised of ground floor only.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Directorate of Education circular	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	GF only	-----	-----
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	GF only	-----	-----
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 mts	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A

	<ul style="list-style-type: none"> Total numbers Types IS marking 	05 nos. ABC type ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	---- 30 m 5 mm	N/A N/A N/A	N/A N/A N/A
7	Automatic fire detection and alarming system Not required			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual 	--- N/A N/A N/A N/A N/A N/A N/A	----- N/A N/A N/A N/A N/A N/A N/A	----- N/A N/A N/A N/A N/A N/A N/A

	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.	Not Applicable		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	01 ABC type fire extinguisher is provided near elect. Panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/2006/1919 dated 04.08.2006, renewal under the Directorate of Education circular No. 262 -362 dated 17-01-2005 is recommended.

DFA is put up for approval & signature please

DCFO (D.P. Bhardwaj)

16/5/16

(M.K. CHATTOPADHYAY)
ADO (MRD)

12/5/2016