

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/2016/Banquet/NDZ/826

Dated: 20/05/16

FIRE SAFETY CERTIFICATE

Certified that the City Palace (Banquet Hall), 447, Jheel Khurenja, Delhi-51, comprised of ground plus one upper floor owned/occupied by M/S City Palace, was granted FSC by this department vide letter no. F6/DFS/MS/2013/NDZ/839 dated 03.09.2013. The Banquet Hall was re-inspected by the officer concerned of this department on 13.05.2016 in the presence of Mr. Satpal Singh, Owner of the Banquet hall and found that the Banquet hall have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and found that the Banquet hall having GF+FF is fit for occupancy class "Assembly (Banquet hall)" with effect from 20/05/16..... for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on...20/05/16.....at New Delhi by


(Rajesh Panwar)

Dy. Chief Fire Officer

Ph. 011-23412025

o/c ssm

To,

Mr. Satpal Singh,

City Palace (Banquet Hall), 447, Jheel Khurenja, Delhi-51

Copy to-

The Dy. Health Officer,

East Delhi Municipal Corporation, Shahdara (North) Zone, Delhi

CONDITIONS:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : City Palace (Banquet Hall), 447, Jheel Khurenja, Delhi-51.
 2. Building is comprised of : G+1
 3. Type of Occupancy : Assembly (Banquet Hall)
 4. Type of Case : Renewal
 5. Details of Previous FSC : F6/DFS/MS/2013/NDZ/839 dated 03.09.2013
 6. Fire Safety direction letter No : F6/DFS/MS/BP/2013/1622 dated 18.06.13
 7. Date of Inspection : 13.05.2016
 8. Name of the Inspecting Officers: : Suresh singh (ADO)
 9. Name of the designation of Officer
 from the building side : Mr. Satpal Singh, Owner
 10. Year of Construction :
 11. Applicant's letter No : dated 06.05.2016

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement/ NBC	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	17 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 no.	02 no.	MR
	Basement	N.A.	N.A.	N.A.
	b. Width of Staircases			
	Upper Floor	1.5 m	2 m, 1.65 m	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	2hr rating	Provided	MR
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	01 no.	Provided	MR
	g. Width of Corridor			
h. Door Size	2 m	2 m, 2 m	MR	
i. No. of Door	2 no.	2 no.	MR	
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	N.A.	N.A.

20/14

5.	Fire Extinguisher			
	Total numbers	06 no.	06 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters's location	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants of each floor	1 no.	01 no.	MR
	Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

N/15

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	15,000 Liters	15,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	62 KVA Generator Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	Required	CO ₂ local application in electrical pannel provided	MR

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter no. F6/DFS/MS/2013/NDZ/839 dated 03.09.2013 renewal under the Rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Singh 13.5.16

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO (SHAH)

Dy. CFO (Vijendra Singh)

Submitted for approval please

Dy CFO (NDZ)

Vijendra Singh
16/5/16