

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2016 / *school/w2/810*

Dated: *19/05/2016*

FIRE SAFETY CERTIFICATE

Certified that the **Darshan Academy, Kirpal Bagh, Delhi-110009** comprised of two blocks i.e. **Ground and 03 upper floors & Ground floor buildings** owned/ occupied by Darshan Education Foundation was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/2012/School/4547 dated 11.12.2012**. The premise was re-inspected by the officer concerned of this department on **28.04.2016** in the presence of **Sh. A. David (Principal)** and observed that all the fire prevention and **fire** safety arrangements as provided in the premise found in good working condition and there is no additional construction. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from *...19/05/16...* for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhi.govt.nic.in

Issued on *19/05/16*..... at New Delhi


(Dr.G.C. Misra)
Director

Ph:-011-23414000
o/cdu

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Darshan Academy, Kirpal Bagh, Delhi-110009.

N/18

INSPECTION REPORT

1. Name & address of the building :Darshan Academy, Kirpal Bagh, Delhi-110009.
2. Type of Occupancy :Educational
3. Type of Case :Renewal - 2 blocks(GF—01block, G+03—01 block)
4. Details of previous NOC :F-6/DFS/MS/2012/School/4547 dated 11.12.2012
5. Fire Safety directives letter No : Director of Education Circular dated 17.01.2005
6. Date of inspection : 28/04/2016
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Mr A David /Principal
9. Year of Construction : 1997/2000
10. Applicant's letter No. : DA/KB/ E-1371/2016 dated 26.03.2016

Plot Area-15000 sq yard Covered Area:3304 sq.yard class rooms -43 students---1061 nos

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education letter dated 17.01.2005	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	9 m	MR
	• Gate width	4.5m	6 m	MR
	• Width of internal road	6m	6 m	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.62m & 1.41 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	2	MR
	e. Width of Corridor	1.50m	2m	MR
f. Door Size	1 m	1.00 m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA

M/19

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	17 nos	17 nos	MR
		ABC/Co2	ABC-16 / Co2- 1	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02	P	MR
		30m	30m	MR
		5mm	P	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	One 100mm	P	MR
		One	P	MR
		One	P	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA

(Handwritten mark)

N/20

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		R	P	MR
		450lpm	P	MR
		40m	P	MR
		R	P	MR
		R	P	MR
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> • Overhead Tank capacity 	10,000 ltrs	10,000ltrs	MR
15	Exit Signage.			
		R	P	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Lift Signage 	N/A	N/A	N/A
17	Standby power supply			
		N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Location 	N/A	N/A	N/A
19	Fire Control Room			

Handwritten signature

N/21

	<ul style="list-style-type: none"> • Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

The school management has complied all the observations issued & communicated by this department vide letter of even no. 531 dated 26.02.2016.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular / NBC Part 4, the FSC issued vide letter of even no 4547 dated 11.12.2012 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended

[Handwritten Signature]
9/5

Signature of the Inspecting Officer

Name :- Rajesh Kumar

Designation:- ADO/RN

[Handwritten Signature]
DO P/WO

[Handwritten Signature]
Rajesh
9/5/16

[Handwritten Signature]