

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/2016/NDZ/BNQT/827

Dated: 20/05/16

FIRE SAFETY CERTIFICATE

Certified that the Kanishka Banquet, Property No. D-35-36, Main Road Kanti Nagar, Delhi, comprised of ground plus one upper floors owned/occupied by Kanishka Banquet, was granted FSC by this department vide letter no. F6/DFS/MS/2013/NDZ/485 dated 26.06.2013. The Banquet Hall was re-inspected by the officer concerned of this department on 13.05.2016 in the presence of Mr. Rakesh Nagpal, Owner of the Banquet hall and found that the Banquet hall have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and found that the Banquet hall having GF+FF is fit for occupancy class "Assembly (Banquet hall)" with effect from 20/05/16..... for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on 20/05/16..... at New Delhi by


(Rajesh Panwar)

Dy. Chief Fire Officer

Ph. 011-23412025

f/c Sh

To,

Sh. Rakesh Nagpal,

Kanishka Banquet, Property No. D-35-36, Main Road Kanti Nagar, Delhi Delhi-51

Copy to-

The Dy. Health Officer,

East Delhi Municipal Corporation, Shahdara (North) Zone, Delhi

CONDITIONS:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/7

INSPECTION REPORT

1. Name & address of the building : Kanishka Banquet, Property No. D-35-36, Main Road
Kanti Nagar, Delhi-51
2. Building is comprised of : G+1
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/2013/NDZ/485 dated 26.06.2013
6. Fire Safety direction letter No : F6/DFS/MS/BP/2013/877 dated 01.03.13
7. Date of Inspection : 13.05.2016
8. Name of the Inspecting Officers: : Suresh singh (ADO)
9. Name of the designation of Officer
from the building side : Mr. Rakesh Nagpal, Owner
10. Year of Construction :
11. Applicant's letter No : Nil

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6.10 m	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 no.	2 no.	MR
	Basement	NA	NA	NA
	b. Width of Staircases			
	Upper Floor	1.5 m	1.5 m each	MR
	Basement	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	1 no.	1 no.	MR
	g. Width of Corridor	NA	NA	NA
h. Door Size	2 m	2 m, 1.7 m	MR	
i. No. of door	2 no.	2 no.	MR	
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	NA	NA	NA
	Fire rating of shaft door	NA	NA	NA
	Water curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4	Smoke Management System. Ventilated			
	Basement	30a/cper hour	NA	NA
	Upper floor	12a/cper hour	NA	NA

n/8

5.	Fire Extinguisher			
	Total numbers	10 no.	10 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	NA	NA	NA
	Location of main panel	NA	NA	NA
	Location of repeater panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters's location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	basement	NA	NA	NA
	upper floor	NA	NA	NA
	sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants of each floor	1 no.	01 no.	MR
	Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

N/9

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	15,000 Liters	15,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication in lift car	NA	NA	NA
	Firemen's grounding switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	Total area	NA	NA	NA
	Location	NA	NA	NA
19	Fire Control Room			
	Detector system panel	NA	NA	NA
	Flow switch panel	NA	NA	NA
	PA system panel	NA	NA	NA
	Batter backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter no. F6/DFS/MS/2013/NDZ/485 dated 26.06.2013 renewal under the Rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Singh
13.5.16

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO (SHAH)

Dy.CFO (Virendra Singh)

Submitted for approval please.

Vingh
16/5/16