

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

E-mail: gargatul@hotmail.com, Tel:- 011-26189168

No. F6/DFS/MS/School/2016/ 82/804

Dated: 19/05/16

FIRE SAFETY CERTIFICATE

Certified that **Lakshya Deep Public School located at L-1003, Gali No.-15, Sangam Vihar, New Delhi- 110080** comprised of ground and one upper floor was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2006/1330 dated 15/06/2006. The school building was re-inspected by the officer concerned of this department on 11/05/2016 in presence of Mr. Yatinder Kumar, Manager of the school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. 262-362 dated 17-01-2005 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the under mentioned conditions.

Issued on 19/05/16 at New Delhi by.


(ATUL GARG)

Dy. CHIEF FIRE OFFICER

Copy to: -

1. The Manager, Lakshya Deep Public School, L-1003, Gali No.-15, Sangam Vihar, New Delhi- 110080.
2. The Directorate of Education, Old Secretariat, GNCT of Delhi, NewDelhi- 110006.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Lakshya Deep Public School, L-1003, Gali No.-15, Sangam Vihar, New Delhi- 110080.
1. Type of Occupancy : Educational
2. Type of Case : Renewal
3. Details of previous NOC : F6/DFS/MS/School/2006/1330 dated 15/06/2006
4. Fire Safety directives letter No : Directorate of Education circular No. 262-362 dated 15.06.2006
5. Date of inspection : 11.05.2016
6. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO (M.Rd)
7. Name and designation of officers from the building side : Mr. Yatinder Sharma, Manager
9. Year of Construction : 2005
10. Applicant's letter No. : LDPS/01/2016-17 dated 22.04.2016.

Lakshya Deep Public School is comprised of ground and one upper floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Directorate of Education circular	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02 Nos.	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts or less & 0.75 mt	1.13 & 0.75 mts	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	Provided (01)	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 mts	Provided (1.0 mt)	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			

	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	225 LPM	Provided	MR
	➤ Head of the pump	35 mts.	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Starting switch at GF	MR
14	Captive Water Storage for firefighting	Not required		
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2500 lts.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Not Applicable		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	01 ABC type fire extinguisher is provided near elect. Panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/School/2006/1330 dated 15/06/2006, renewal under the Directorate of Education circular No. 262-362 dated 17-01-2005 is recommended.

DFA is put up for approval & signature please

DCFO (D.P. Bhardwaj)


16/5/16


13/5/16
Name (M.K. CHATTOPADHYAY)
Assistant Divisional Officer (MRD)