

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFR/MS/EH/2016/MD2/855

Dated: 24/05/16

**FIRE SAFETY CERTIFICATE**

Certified that the Kocktails and Kurries Restaurant (a unit of Parish Enterprises Pvt.Ltd.) running at first & second floor only of building at Atlantic Plaza,Plot No.4,L.S.C-II,I.P.Extn.,Delhi-92, owned /occupied by M/s Parish Enterprises Pvt.Ltd.,comprised of ground plus three upper floors was granted fire safety certificate vide letter no.F6/DFS/MS/EH/2013/NDZ/470 dated 24.06.2013.The building was inspected by the officer concerned of this department on 12.05.2016 in the presence of Manager and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 and that first & second floor only of the building is fit for occupancy Group "Assembly Building/ Restaurant" with effect from 24/05/16... for a period of three years, subject to conditions printed overleaf.

Issued on 24/05/16 at New Delhi by



(Rajesh Panwar)  
Dy.Chief Fire Officer  
Ph. 011-23412025

To,

1. Kocktails and Kurries Restaurant (True Blue)  
M/s Parish Enterprises Pvt.Ltd.  
Atlantic Plaza,Plot No.4,L.S.C-II,I.P. Extn.,Delhi -92.
- 2.Assit. Director (Tourism)  
Tourism Dewpartment, Room No.176,  
Old Secretariat, Delhi-54.

*Handwritten initials*

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation,ventilation,structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. All comments/ directions of the Licensing Department shall always be permitted and followed.
6. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized if any.
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building : Kocktails and Kurries Restaurant(True Blue) at First & second floor at L.S.C.II,Atlantic Plaza,Plot No.4,I.P.Extension, Patparganj, Delhi -92.
2. Type of Occupancy : Restaurant (Assembly )
3. Type of Case : Renewal
4. Details of Previous FSC : F.6/DFS/MS/EH/2013/NDZ/470 dated 24.06.13
5. Fire Safety directives No : F.6/ MS/ DFS/2005/718 dated 04.04.16
6. Date of Inspection : 12.05.16
7. Name of the Inspecting Officer : ADO R.K.Yadav
8. Name of the designation of Officer  
From the building side : Manager
9. Year of Construction : 2002
- 10.Applicant's letter No :16.04.16

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	old Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> <li>Road width</li> </ul>	4.5 Mtrs	15 Mtrs.	MR
	<ul style="list-style-type: none"> <li>Gate width</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Width of internal road</li> </ul>	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	2 Nos.	01 No.+ 01 No. staircase through adjoining building	MR
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	1.25 M	1.20 & 1.10 M	MR
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1 No.	1 No.	MR
		N/A	N/A	N/A
	g. Width of Corridor	1.0 Mtr.	1.0 & 1.10 M	MR
	h. Door Size			
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	Required	Sealed	MR
	<ul style="list-style-type: none"> <li>Fire rating of shaft door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Water curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper floor</li> </ul>	N/A	N/A	N/A
5.	Fire Extinguisher			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	08 no.	10 No.	MR
	<ul style="list-style-type: none"> <li>types</li> </ul>	ABC & Co2	ABC & Co2	MR
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers of each floor</li> </ul>	1 no.	Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	Provided	MR

7.	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters's location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	provided	MR
10	Automatic Sprinkler System.			
	• basement	N/A	N/A	N/A
	• upper floor(1 <sup>st</sup> & 2 <sup>nd</sup> floor)	Required	provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	225 LPM	225 LPM	MR
	➤ Head of Main Pump	35 M	35 M	MR
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450LPM	450 LPM	MR
	➤ Head of the Pump	35 M	35 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5000 Ltrs.	5000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

N/13

19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The fire safety certificate issued vide letter no. :F.6/DFS/MS/EH/2013/NDZ/470 Dated 24.06.13 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*R.K. Yadav*  
18/5/2016

Signature of the Inspecting Officer  
Name:-R.K.Yadav  
Designation :-ADO(LN)

DCFO(Virendra Singh)

Submitted for approval please.

*Virendra Singh*  
18/5/16

Dy CFO (NDZ)

*Virendra Singh*  
19/5

~~Director~~  
*Virendra Singh*  
19/5