

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/EM/2016/W2/858

Dated: 25/05/16

FIRE SAFETY CERTIFICATE

Certified that the **M/S Devour Foods Concept, B-1/6 Ground Floor, Ashok Vihar Ph -2 Delhi-110052.** on Ground Floor of premises comprised of Basement+ Ground +3 upper Floors owned /occupied by **M/S Devour Foods Concept** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 11/05/2016 in the presence of **Sh Gurpreet singh (Owner)** that the premises is fit for occupancy class "**Assembly**" **Group D** with effect from 25/05/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/05/16 at New Delhi by.

  
(Dr. G.C. Misra)  
Director,  
Ph: - 011-23414000

Copy to:

1. Dy. Health Officer, Civil Line Zone,16, Raj pura Road, Delhi-110054
2. Sh Gurpreet singh Singh M/S Devour Foods Concept, B-1/6 Ground Floor, Ashok Vihar Ph -2 Delhi-110052.
3. Following fire safety directives must be adhered to:-
  1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
  2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
  3. The trained staff should be available round the clock.
  4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
  5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
  6. Basement shall be used as per building bye laws 1983.
  7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

The Restaurant was re inspected to see the compliance of shortcomings noticed during the inspection dated 16/03/2016.

**INSPECTION REPORT**

1. Name & address of the building: **M/S Devour Foods Concept, B-1/6  
Ground Floor, Ashok Vihar Ph -2 Delhi-110052.**
2. Type of Occupancy : **Assembly (Restaurant)**
3. Type of Case : **New (At Ground Floor in the building  
comprised of Basement + Ground + 3 Upper Floor )**
4. Details of previous NOC : **Nil**
5. Fire Safety directives Letter No. : **Nil**
6. Date of inspection : **11/05/2016**
7. Name of the Inspecting Officer : **ADO (WP)**
8. Name and designation of Officer  
from the building side : **Sh. Gurpreet Singh**
9. Year of Construction : **2000-2001**
10. Applicant's letter No. : **Nil dated 26-04-2016**

| Sr. No | Minimum standards on fire prevention and fire safety U/R 33 | NBC/BBL Requirements | Provided at site        | Remarks MR/NMR                           |
|--------|---|----------------------|-------------------------|--|
| 1.     | Access of building  | 6 mtr.               | Provided                | MR                                       |
|        | • Road width  | NA                   | NA                      | NA                                       |
|        | • Gate width  | NA                   | NA                      | NA                                       |
|        | • Width of internal road                                    | NA                   | NA                      | NA                                       |
| 2.     | Number, width, Type & Arrangements of exits                 |                      |                         |  |
|        | a. Number of staircases                                     | NA                   | 01 Provided             | NA                                       |
|        | • Upper floors  | NA                   | 02 Provided             | NA                                       |
|        | • Basements   |                      |                         |  |
|        | b. Width of staircases                                      | NA                   | NA                      | NA(One Stair of 1mtrs width is Provided) |
|        | • Upper floors  | NA                   | NA                      | NA( Have Separate entry)                 |
|        | • Basements   |                      |                         |  |
|        | c. Protection of exits                                      |                      |                         |  |
|        | • Fire check door   | NA                   | NA                      | NA                                       |
|        | • Pressurization  | NA                   | NA                      | NA                                       |
|        | d. No of continuous staircase to terrace                    | NA                   | Provided                | NA                                       |
|        | e. Width Of Corridor  | NA                   | NA                      | NA                                       |
|        | f. Door Size  | 1x2 mtr. & 1x1mtr    | Provided(1x2m & 1x1.5m) | MR                                       |

|     |   |             |          |      |
|-----|---|-------------|----------|------|
| 3.  | Compartmentation  |             |          |      |
|     | <ul style="list-style-type: none"> <li>• Fire check door</li> </ul>                     | NA          | NA       | NA   |
|     | <ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>        | NA          | NA       | NA   |
|     | <ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>           | NA          | NA       | NA   |
|     | <ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>                       | NA          | NA       | NA   |
|     | <ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>                        | NA          | NA       | NA   |
| 4.  | Smoke managements System  |             |          |      |
|     | <ul style="list-style-type: none"> <li>• Basements</li> </ul>                           | NA          | NA       | NA   |
|     | <ul style="list-style-type: none"> <li>• Upper floors( For Restaurant Floor)</li> </ul> | NA          | NA       | NA   |
| 5.  | Fire Extinguishers  |             |          |      |
|     | <ul style="list-style-type: none"> <li>• Total numbers</li> </ul>                       | 2 ABC / CO2 | 2        | MR   |
|     | <ul style="list-style-type: none"> <li>• Types</li> </ul>                               |             | Provided | MR   |
|     | <ul style="list-style-type: none"> <li>• IS marking</li> </ul>                          | ISI marked  | Provided | MR   |
| 6.  | First – Aid Hose Reels  |             |          |      |
|     | <ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>         | 1           | Provided | MR ✓ |
|     | <ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>            | 30 m        | Provided | MR   |
|     | <ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>                     | 5 mm        | Provided | MR   |
| 7.  | Automatic fire detection and alarming system  |             |          |      |
|     | <ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>                   | NA          | NA       | NA   |
|     | <ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>              | NA          | NA       | NA   |
|     | <ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>          | NA          | NA       | NA   |
|     | <ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>           | NA          | NA       | NA   |
|     | <ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>                   | NA          | NA       | NA   |
| 8.  | MOEFA   | Required    | Provided | MR ✓ |
| 9.  | Public Address System   | NA          | NA       | NA   |
| 10. | Automatic Sprinkler System  |             |          |      |
|     | <ul style="list-style-type: none"> <li>• Basements</li> </ul>                           | NA          | NA       | NA   |
|     | <ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>                         | NA          | NA       | NA   |
|     | <ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>       | NA          | NA       | NA   |
| 11. | Internal Hydrants:  |             |          |      |
|     | <ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>            | 100 mm      | Provided | MR ✓ |
|     | <ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>        | 1           | Provided | MR   |
|     | <ul style="list-style-type: none"> <li>• Hose Box</li> </ul>                            | 1           | Provided | MR   |

|     |   |                |          |    |
|-----|---|----------------|----------|----|
| 12. | Yard Hydrants   |                |          |    |
|     | • Total number of hydrants                                  | NA             | NA       | NA |
|     | • Hose Box  | NA             | NA       | NA |
| 13. | Pumping Arrangements:                                       |                |          |    |
|     | • Ground Level  |                |          |    |
|     | • Discharge of main pump                                    | NA             | NA       | NA |
|     | ➤ Head of main pump   | NA             | NA       | NA |
|     | ➤ Number of main pumps                                      | NA             | NA       | NA |
|     | ➤ Jockey pump out put                                       | NA             | NA       | NA |
|     | ➤ Jockey pump head  | NA             | NA       | NA |
|     | ➤ Standby Pump out put                                      | NA             | NA       | NA |
|     | ➤ Standby Pump Head   | NA             | NA       | NA |
|     | ➤ Auto Starting/Manual stopping                             | NA             | NA       | NA |
|     | ➤ Pump House Access   | NA             | NA       | NA |
|     | • Terrace level   |                |          |    |
|     | ➤ Discharge of pump   | 450 lpm        | Provided | MR |
|     | ➤ Head of the pump  | 40 m           | Provided | MR |
|     | ➤ Power supply  | Required       | Provided | MR |
|     | ➤ Auto starting of pump                                     | Required       | Provided | MR |
| 14. | Captive water Storage for fire fighting:                    |                |          |    |
|     | • Under ground tank capacity                                | NA             | NA       | NA |
|     | ➤ Draw off connection                                       | NA             | NA       | NA |
|     | ➤ Fire service inlet  | NA             | NA       | NA |
|     | ➤ Access to tank  | NA             | NA       | NA |
|     | • Overhead Tank capacity                                    | 10, 000 liters | Provided | MR |
| 15. | Exit Signage  | Required       | Provided | MR |
| 16. | Provision of Lifts ( <b>Lift Provided for upper Floor</b> ) |                |          |    |
|     | ➤ Pressurization of Lift Shaft                              | NA             | NA       | NA |
|     | ➤ Pressurization of lift lobby                              | NA             | NA       | NA |
|     | ➤ Communication in lift Car                                 | NA             | NA       | NA |
|     | ➤ Fireman's Grounding Switch                                | NA             | NA       | NA |
|     | ➤ Lift Signage  | NA             | NA       | NA |
| 17. | Standby power supply  | Required       | Provided | MR |
| 18. | Refuge Area   |                |          |    |
|     | ➤ Total area  | NA             | NA       | NA |
|     | ➤ Location  | NA             | NA       | NA |
| 19. | Fire control room   |                |          |    |
|     | ➤ Detector system panel                                     | NA             | NA       | NA |
|     | ➤ Flow Switch Panel   | NA             | NA       | NA |
|     | ➤ PA System Panel   | NA             | NA       | NA |
|     | ➤ Battery backup  | NA             | NA       | NA |
|     | ➤ Building Floor Plans                                      | NA             | NA       | NA |

|  |    |    |    |
|--|----|----|----|
| 20. Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |
|--|----|----|----|

\*

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers .....11.....

Note;- The Restaurant is open at Ground floor, Basement is being used for Gym & Uppers Floors for residence and segregated have separate entry exit..

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name Uday Vir Singh

Name

Designation AAO/WP

Designation

~~No/O~~ 12/5/16

Director

contact 16/5

74/Dch/20  
17/5/16.