

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

Dated: 26/5/16

No. F6/DFS/MS/2016/862

FIRE SAFETY CERTIFICATE

Certified that the M/s Prisha Projects LLP located at Plot No. 6, Block No.6, Kirti Nagar Industrial Area, New Delhi - 110015 in a building comprised of Basement + Stilt + Ground + 2 Upper Floors owned/ occupied by M/s Prisha Projects LLP have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 20-05-2016 in the presence of Mr. V K Gandhi (Designated Partner) and found that the said building / premises is fit for occupancy class " Industrial" Group G with effect from 26/5/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/5/16..... at New Delhi by.


Director,
Delhi Fire Service.

Copy to:

1. Sh. V K Gandhi (Designated Partner),
M/s Prisha Projects LLP,
Plot No. 6, Block No. 6, Kirti Nagar Industrial Area, New Delhi - 110015.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per Building Bye Laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: M/s Prisha Projects LLP, Plot No. 6, Block No. 6, Kirti Nagar Industrial Area, New Delhi – 110015.
2. Type of Occupancy : Industrial (Basement + Stilt + Ground + 2 Upper Floors)
Height = 14.95m.
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2014/281 dated 10-10-2014 and F6/DFS/BP/2014/227 dated 21-08-2014
6. Date of inspection : 20-05-2016
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer
from the building side : Sh. V K Gandhi (Designated Partner)
9. Year of Construction : 2016
10. Applicant's letter No. : Nil dated 13-04-2016

Plot Area=1866.66 sqm.
Basement=Storage, Stilt=Parking
Ground + 2 Upper Floors =
Industry .

S No	Minimum standards on fire prevention and fire safety U/R	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	18 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5m	Provided	MR
	• Basements	1.5m	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	2 Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			

	<ul style="list-style-type: none"> Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	20 nos.	Provided	MR
	<ul style="list-style-type: none"> Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	2	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	Smoke & Heat	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	2	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	2	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NR	NR	NR
	<ul style="list-style-type: none"> Hose Box 	NR	NR	NR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	2280 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of main pump 	60 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	1	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	180 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey pump head 	60 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	2280 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	60 m	NR	MR
	<ul style="list-style-type: none"> ➤ Auto Staring/Manual stopping 	Required	NR	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 	Required	NR	MR
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	900 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump 	Required	Provided	MR

14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	1 lac litres	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	NR	Provided	NR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Note: The premises having the facility of Mechanical Lift is now not provided. The basement is used for the storages purposes in place of parking.

Signature of the Inspecting Officer
 Name *Mukesh Verma*
 Designation *ASO (MN)*

DO (next)

Signature of the Inspecting Officer
 Name
 Designation