

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Email:gargatul@hotmail.com, Tel:- 011-26189168

NO.F6/DFS/MS/2016/ 52/875

Dated: 26/5/16

FIRE SAFETY CERTIFICATE

Certified that Delhi Tamil Sangam located at Tamil Sangam Marg, Sec-5, Ramakrishnapuram, New Delhi-110022. Comprised of two blocks – Old Block: - Basement, Ground & two upper floors and New Block: - Basement, ground floor, mezzanine floor, first floor & second floor (The basement and ground floor is common for old & new block) owned/occupied by Delhi Tamil Sangam was issued NOC vide letter no. F.6/MS/ DFS/2001/1103 dated:11/06/2001. The premises was re- inspected by the officer concerned of this department on 10/05/16 in the presence of Mr. Murthy and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Mixed (Business, Assembly & Mercantile) with effect from 26/05/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 26/05/16 at New Delhi by.


(ATUL GARG)
CHIEF FIRE OFFICER



Copy to:-

Mr. N Kannan (General Secretary),
Delhi Tamil Sangam,
Tamil Sangam Marg, Sec-5,
Ramakrishnapuram, New Delhi-110022

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

N115

INSPECTION REPORT

1. Name & address of the building:- Delhi Tamil Sangam, Tamil Sangam Marg, Sec-5, Ramakrishnapuram, New Delhi-110022
2. Type of occupancy:- Mixed Occupancy (Business, Assembly & Mercantile)
3. Type of case:- Renewal
4. Details of previous NOC:- F.6/ MS/ DFS/2001/1103 dated:11/06/2001
5. Fire safety directives No.- F.6/DFS/MS/83/Auditorium/213 dated 03/07/1983
F6/DFS/MS/84/786 dated 09/08/1984
6. Date of inspection:- 10/05/2016
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side:- Mr. Murthy
9. Year of construction:- 1990 & 1997
10. Applicant's letter no:- Nil Dated: 21/12/2015 received at HQ on 23/03/2016
11. Composition of building: - Building is in two blocks – Old Block: - basement, Ground floor, first floor & second floor and New Block: - basement, ground floor, mezzanine floor, first floor & second floor. The basement is common for old & new block.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 m	Provided	MR
	2) Gate width	5 m	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	Old Block is served by a single staircase WHICH IS common with new block upto first floor. New Block - 03nos including common staircase.	MR
	2. Basements	02	03nos	MR
	B. Width of staircase			
	1. Upper floors	1.25 m	Old Block- Ground floor to First floor -1.37m First Floor to Second Floor- 1.25m New Block-1.40m,1.37m 1.37m	MR
	2. Basements	1.25 m	1.40m,1.26m & 1.07m	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02	02	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5m for Auditorium & 1 m for others	1.53,1.52m,1.40m,1.40m Balcony-1.37m,1.37m Old Case	MR (Old Case)

3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Provided Exhaust Fans	MR
	2) Upper floors	12 a/c per hour	Auditorium has Exhaust Fans and rest of the building has Natural Ventilation	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	42Nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02nos	Provided	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke	Provided	MR
	2) Location of main panel	Ground Floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Every Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	Provided	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	04nos	Provided	MR
	2) Hose box	04nos	Provided	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280 LPM	Provided	MR
	b) Head of main pump	60m	Provided	MR
	c) Number of main pump	01	Provided	MR
	d) Jockey pump out put	450 LPM	Provided	MR
	e) Jockey pump head	40m	Provided	MR
	f) Stand by pump output	900 LPM	Provided	MR
	g) Stand by pump head	60 m	Provided	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	900 LPM	Provided	MR
	b) Head of pump	54m	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR



2117

Captive Water Storage for Fire Fighting				
	1) Under ground tank capacity	1,00,000 Ltrs.	1,00,000 Ltrs.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	30,000 Ltrs.	30,000 Ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	Provided		N/A

The fire protection system provided in the building were checked and found functional at the time of inspection. In view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules 35 of the Delhi Fire Service rules 2010, renewal of NOC is recommended. Accordingly DFA is put up for signature please.

Signature of the inspecting officer
 Name: - D.B. Mukherjee.
 Designation: - Asstt. Div. Officer (BCP)

12/5/2016

By CFO (D.P. Bhardwaj)

→ CFO-52

Time limit has already gone in this case. Kindly explain why so much delay