

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Email:gargatul@hotmail.com, Tel:- 011-26189168

No.F.6/DFS/MS/SZ/Industrial/2016/ 874

Dated: 26/05/16

FIRE SAFETY CERTIFICATE

Certified that Intex located at A-61, Okhla Industrial Area, Phase II, New Delhi-110020 comprised of two tier basement, stilt, ground plus 02 upper floors owned / occupied by Intex Technologies (India) Ltd. was inspected by the officer concerned of this department on 10/05/2016 in the presence of Mr. Arup Chhaterjee and found that the said building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class- G, Industrial Building(Moderate Hazard) with effect from 26/05/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 26/05/16 at New Delhi by


(ATUL GARG)
CHIEF FIRE OFFICER (SZ)

07c Arup Chhaterjee (BCL)

Copy to:-

The Authorized Signatory
Intex Technologies (India) Ltd.
D-18/2, Okhla Industrial Area Ph-II,
New Delhi-110020

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

2/3
INSPECTION REPORT

1. Name & address of the building: - Intex, Plot No. A- 61, Okhla Industrial Area Ph -II, New Delhi-20
2. Type of occupancy:- Industrial (Moderate Hazard)
3. Type of case: -New
4. Details of previous NOC: - Nil
5. Fire safety directives No.- F6/DFS/MS/BP/2014/141 dated 27/05/14
6. Date of inspection:- 10/05/2016
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mr. Arup Chhaterjee
9. Year of construction:- 2016
10. Applicant's letter No:- Nil dated: 29/03/2016
11. Composition of building: - Two tier basement, stilt, ground + 02 upper floors.

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	9m	Provided 18m	MR
	2) Gate width	5m	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02nos	02no	MR
	2. Basements	02 nos	02nos.	MR
	B. Width of staircase			
	1. Upper floors	1.50m	1.50m each	MR
	2. Basements	1.50m	1.50m each	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01no	02 nos.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1m	Provided	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Provided	MR
	2) Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	40Nos. Provided	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02 no.	02 nos.provided at each floor	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke	Provided	MR
	2) Location of main panel	Required	Provided at stilt floor	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided at each floor	MR
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants per floor	02nos	Provided	MR
	3) Hose box	02nos	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	07nos	Provided	MR
	2) Hose box	07nos.	Provided	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280Lpm	Provided	MR
	b) Head of main pump	60m	Provided	MR
	c) Number of main pump	01no	Provided	MR
	d) Jockey pump out put	180Lpm	Provided	MR
	e) Jockey pump head	60m	Provided	MR
	f) Stand by pump output	2280Lpm	Provided	MR
	g) Stand by pump head	60m	Provided	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	900LPM	Provided	MR
	b) Head of pump	40mtr	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	10,000ltr	Provided	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	Required	Provided	MR
	b) Pressurization of lift lobby	Required	Provided	MR
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided DG Set	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A

[Handwritten mark]

N/S

19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire system provided in the building found functional at the time of inspection.
 In view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules 35 of the Delhi Fire Service Rules 2010 is recommended to grant fire safety certificate.
 Accordingly DFA is put up for perusal and signature pl.

[Signature]
 12/5/2016

Signature of the inspecting officer
 Name: - D.B.Mukherjee.
 Designation:- Assistant Divisional Officer (BCP)

Dy CFO (D.P. Sharda) *[Signature]*

[Signature]
 20/5/16

[Signature]
 20/5/16

~~DIRECTOR~~ *[Signature]*
 25/6