

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2016/SZ/ 870

Dated: 26/5/16

FIRE SAFETY CERTIFICATE

Certified that the New Sainik Public School located at RZ-F-3, Nand Ram Park, Mahavir Enclave, Part-III, New Delhi – 110059, building comprised of ground plus two upper floors & two rooms at third floor, **School running at ground & first floor (Second floor being used as residence of owner & two rooms at third floor residence of watch man)** have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Letter No: Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 and verified by the officer concerned of fire service on 18.05.2016 in the presence of Sh. Rajesh Kumar (Manager) and that the school Premises/building is fit for occupancy class B "Educational Building" **for ground & first floor only**, with effect from 26/5/16 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed overleaf.

Issued on 26/5/16 at New Delhi by


(Atul Garg)

Chief Fire Officer

Ph.011-26189168

Copy to:

- 1 Director (Education) SDMC, 23rd floor, civic centre, Minto Road, New Delhi.
- 2 Manager, New Sainik Public School located at RZ-F-3, Nand Ram Park, Mahavir Enclave, Part-III, New Delhi – 110059.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	New Sainik Public School, RZ-F-3, Nand Ram Park, Mahavir Enclave Part-III , New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	Directorate Of Education Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	18.5.2016		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Rajesh Kumar (Manager)		
9	Year of construction	2003, 2009		
10	Applicant's letter No.	10.5.2016	Ground plus Two upper floors & 2 Rooms at third floor (School running at ground & first floor) 2nd floor resi. of owner & 3rd floor resi. of watchman.	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/ Director EDU CIR. Dt. 01.03.2011	Provided at site	Remarks MR / NMR
--------	---	---	------------------	---------------------

1	Access to building			
	1) Road width	Accessible	9 Mtrs.	MR ✓
	2) Gate width	Approachable	1.75 Mtrs.(Abute on Road)	MR ✓
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	One of 1.5 Mtrs.(If less than 1.5 Mtrs. then required Two Nos.	Three	MR ✓
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs. if less, required additional of .75 Mtr.	1.14, 87, 74 Mtr.	MR ✓
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	Two	MR ✓
	e. Width of corridor	1.01 Mtrs.	1.05 Mtrs.	MR ✓
	f. Door size	1 Mtr.	1 Mtr.	MR ✓

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	N/A	N/A	N/A

5	Fire Extinguishers			
	total numbers	1 Co2 OR ABC for every 300 Sq. Mtrs.	5 Nos.	MR ✓
	Types	ISI Marked	DCP & ABC	MR ✓
	ISI marking	ISI Marked	ISI Marked	MR ✓

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	N/A		

The Fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rules, issuance of fire safety certificate is recommended under rule 35 of the Delhi Fire Service Rules, 2010 is recommended for ground & first floor.

Accordingly DFA is put up for approval and signature please.

Sweet
19/5/16

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)

DFA

K. T. Singh
19/5/16

Dy CFO (CS)
A. H. S.
20/5/16

DIRECTOR
[Signature]