

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2016 / W2 / 891

Dated: 30/05/2016

FIRE SAFETY CERTIFICATE

Certified that the M/s **Laxmi Ice and Cold Storage located at 7652/1, G.T.K.Road Subzi Mandi, Delhi-110007** comprised of **ground floor only** owned/occupied by M/s Laxmi Ice Cold Storage has already been issued Fire Safety Certificate for running trade of Ice Factory vide this office letter no. **F-6/DFS/Ms/2013/53 dated 12.03.2013**. The premise have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and verified by the officer concerne4d of Fire Service on 19.05.2016 in presence of Sh. Rajesh Yadav ,Manager of the premise is fit for Class G (G-I) Industrial occupancy with effect from 30/05/16.... for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 30/05/16..... at New Delhi

W2/29/15
(Vipin Kental)
Chief Fire Officer
Ph:-011-23846352

Copy to :-

1. The Dy. Health Officer, NDMC, Civil Line Zone, 16, Rajpur Road, Delhi - 54.
2. M/s Laxmi Ice and Cold Storage, 7652/1, G.T.K.Road, Subzi Mandi, Delhi-110007.

2/11
INSPECTION REPORT

1. Name & address of the building : M/s Laxmi Ice & Cold Storage 7652/1, G.T.K.Road, Sabzi Mandi, Delhi-07
2. Type of Occupancy : Ice Factory at Ground Floor only ✓
3. Type of Case : Renewal ✓
4. Details of previous NOC : Nil ✓
5. Fire Safety directives letter No : --
6. Date of inspection : 19/05/2016
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Sh. Rajesh Yadav (Manager)
9. Year of Construction : 1957 (Single Story)
10. Applicant's letter No. : DHO/CLZ/2016/173 Dated-25.04.2016

Plot Area-625 sq.y

Covered Area:412 m2

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	3.5m(old case)	MR(old case)
	• Gate width	4.5m	3.5m(old case)	MR(oldcase)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	NA	NA	NA	

2/19

3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	06nos	06nos	MR
	• Types	ABC/CO2	0 2- WCo2,02-ABC, 02 -Co2	MR
	• ISI marking	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	R	P	MR
	• Length of hose reel hose	30m	P	MR
	• Nozzle diameter	5mm	P	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA

N/13

11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 lpm	450 lpm	MR
		40mtr	40mtr	MR
		N/A	NA	N/A
		N/A	NA	N/A
		14	Captive Water Storage for fire fighting.	
<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA		NA	NA
	NA		NA	NA
	NA		NA	NA
	NA		NA	NA
	5000 ltr		5,000ltrs	MR
15	Exit Signage.	R	P	MR

M

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:			
	N/A	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required under it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

AK
23/5

Signature of the Inspecting Officer

Name :- Rajesh Kumar

Designation:- ADO/RN

DO/NOO

DO/NOO
23/5/16

DO/NOO

DO/NOO
23/5/16

142/DO/NOO
23/5/2015