

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Email:gargatul@hotmail.com, Tel:- 011-26189168


No. F6/MS/DFS/EH/2016/ 52/864

Dated: 26/05/16

FIRE SAFETY CERTIFICATE

Certified that the Barbeque Nation (a unit of Barbeque Nation Hospitality Ltd.) (formerly Pacific Develcon Pvt. Ltd.) located at plot no.-11, Local Shopping Center, Sec.-C, Pocket 6 & 7, Vasant Kunj, New Delhi-110070, comprised of basement, ground + two upper floors. The restaurant is running at ground floor owned/occupied by a unit of Barbeque Nation Hospitality Ltd. was granted FSC by this department vide letter No.F6/DFS/MS/EH/2013/316 dated 18/01/13. The premises was re-inspected by the officer concerned of this department on 19/05/2016 in the presence of Mr. Surajbhan and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Group - D, Assembly Building(Restaurant) with effect from..26/05/16...for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ...26/05/16...at New Delhi by.


(ATUL GARG)
CHIEF FIRE OFFICER

Copy to:-

M/S Barbeque Nation
Plot No11, Local Shopping Center,
Pocket C 6 & 7, Vasant Kunj,
New Delhi- 110070

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Barbeque Nation Plot No11, Local Shopping Center, Sec.-C Pocket 6 & 7, Vasant Kunj, New Delhi- 110070

2. Type of occupancy:- Assembly Building, Group – D, Restaurant

3. Type of case:- Change of name/Renewal

4. Details of previous NOC:- F6/DFS/MS/EH/2013/316 dated 18/01/13.

5. Fire safety directives No.- F6/MS/DFS/BP/2003/2347 dated 01/10/03

6. Date of inspection:- 19/05/2016

7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)

8. Name & designation of officer From the building side:- Mr. Surajbhan

9. Year of construction:- 2005

10. Applicant's letter No:-DHO/NGZ/2015/1741 , dated: 02/5/2016

Building is comprised of Basement, Ground + Two Upper Floors. (Restaurant is running at ground floor)

Sl.No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	9mtrs	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	2nos	2nos.	MR
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	1.5m	1.25m & 1 m	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	02 m	04 nos.- 2m,1.4m, 1.10m & 80cm.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Provided Exhaust Fan	MR
	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	10 Nos.	MR
	2) Types		ABC, Co2 ,Foam	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	Provided	MR
	2) Length of hose reel hose	30m	Provided	MR
	3) Nozzle diameter	5mm	Provided	MR

✓

N/A

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke	Provided	MR
	2) Location of main panel	Ground Floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Every Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants per floor	One	Provided	MR
	3) Hose box	One	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	Required	Provided	MR
	2) Hose box	Required	Provided	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2850 LPM	Provided	MR
	b) Head of main pump	60 m	Provided	MR
	c) Number of main pump	01	Provided	MR
	d) Jockey pump out put	180 LPM	Provided	MR
	e) Jockey pump head	60 m	Provided	MR
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	1,00000 ltrs.	Provided	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A

✓

19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.
 Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures are required under the rules the NOC issued vide letter no F6/MS/DFS/EH/2013/316 dated-18/01/2013 change of name/renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is prepared and put up please.

[Handwritten Signature]
20/5/2016

Signature of the inspecting officer
 Name :- D.B. Mukherjee.
 Designation :- Assistant Divisional Officer (BCP)

Dy cfo (D. P. Bhardwaj)

[Handwritten Signature]
20/5/16

[Handwritten Signature]
20/5/16

DIRECTOR/OPS
[Handwritten Signature]
5/5/15