

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail: gargatul@hotmail.com
No.F.6/DFS/MS/School/2016/SZ 1899

Ph. 011-26189168
Dated: 01.06.2016

FIRE SAFETY CERTIFICATE

Certified that the building of **Kamal Kindergarten**, K-1 Extn., L-Block, Mohan Garden, New Delhi-110059, comprised of ground floor plus three upper floors. The school owned/occupied by the Great Vaibhav Educational & Welfare Society was inspected by the officer concerned of this department on 23.5.2016 in the presence of Sh. V.P Tandon (General Secretary) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on..... 01.06.2016 at New Delhi.


(ATUL GARG)

CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Manager,
Kamal Kindergarten, K-1 Extn., L-Block,
Mohan Garden, New Delhi-110059.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per the building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

211

School building is comprised of ground plus three upper floors and a small basement.
(Kamal Kindergarten, K-1 Extn., L-Block, Mohan Garden, New Delhi-110059)

INSPECTION REPORT

1. Name & address of the building : Kamal Kindergarten, K-1 Extn., L-Block, Mohan Garden, New Delhi-110059.
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of Previous NOC : N/A
5. Fire Safety directives letter No : N/A
6. Date of inspection : 23.5.2016
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. V.P Tandon (General Secretary)
9. Year of Construction : 2009
10. Applicant's letter No. : Nil dated Nil.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ Dt. of edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>—</p> <p>—</p>	<p>06 & 5.5 mtrs</p> <p>04 & 05 mtrs</p> <p>—</p>	<p>M/R ✓</p> <p>—</p> <p>—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>02 No's</p> <p>N/A</p>	<p>02 No's</p> <p>N/A</p>	<p>M/R ✓</p> <p>No basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>150 cms & 125 cms</p>	<p>150 cms & 127 cms</p>	<p>M/R ✓</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>	<p>No basement</p> <p>N/A</p> <p>N/A</p>
	d. No. of continuous staircases to terrace	<p>N/A</p>	<p>One</p>	<p>N/A</p>
	e. Width of Corridor	<p>150 cms.</p>	<p>165 cms</p>	<p>M/R ✓</p>
	f. Door Size	<p>100 cms</p>	<p>100 cms</p>	<p>M/R ✓</p>
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	<p>N/A</p>	<p>N/A</p>	<p>No basement</p>

Sau

2/2

School building is comprised of ground plus three upper floors and a small basement.
(Kamal Kindergarten, K-1 Extn., L-Block, Mohan Garden, New Delhi-110059)

	<ul style="list-style-type: none"> Upper floors 	N/A	Natural ventilation	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	09 no's ABC/CO ₂ type	Provided	M/R ✓
		ISI marked	Provided	M/R ✓
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 no./ floor 30 mtrs 5 mm	Provided	M/R ✓
			Provided	M/R ✓
			Provided	M/R ✓
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

San

13

School building is comprised of ground plus three upper floors and a small basement.
(Kamal Kindergarten, K-1 Extn., L-Block, Mohan Garden, New Delhi-110059)

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		450 LPM	Provided	M/R ✓
		30 mtr	Provided	M/R ✓
		Required	Provided	M/R ✓
		Required	Provided	M/R ✓
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 ltrs	Provided	M/R ✓
15.	Exit Signage.	Required	Provided	M/R ✓
16.	Provision of Lifts.			No Lift
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

See

School building is comprised of ground plus three upper floors and a small basement.
(Kamal Kindergarten, K-1 Extn., L-Block, Mohan Garden, New Delhi-110059)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Note:- As per letter submitted by General Secretary (placed at C-1) the year of construction of building comprised of ground plus three upper floors and a small basement (less than 200 Sq. ft.) is 2009 and there are less than 45 students in each class room.

Sandeep
24/5/16

Signature of Inspecting Officer

Signature of Inspecting Officer

Name:- Sandeep Duggal

Name

Designation:- Asstt. Divisional Officer

Designation

D.O. (South West)

CK Tomar
27/5/16
By CFO (CS2)
25/5/16

Director / OFS
26/5