

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No.

FG/DES/MS/School/2016/ND2/911

Dated:

01/06/16

FIRE SAFETY CERTIFICATE

Certified that the Adarsh Gyan Sarover Balika Vidyalaya, Marginal, Bandh, Main Road (5th Pusta), Ganwari, Delhi-53, comprised of ground plus two upper floors owned/occupied by Adarsh Gyan Sarover Balika Vidyalaya, have complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on dated 17.05.2016 in the presence of Vice Principal of the school and found that the building having GF+FF+SF is fit for occupancy class B 'Educational Building' with effect from01/06/16..... for a period of three years, subject to conditions printed overleaf.

Issued on.....01/06/16.....at New Delhi by


(Rajesh Panwar)

Dy. Chief Fire Officer

Ph. 011-23412025

o/c SP

To,

The Vice Principal

Adarsh Gyan Sarover Balika Vidyalaya,

Marginal, Bandh, Main Road (5th Pusta), Ganwari, Delhi-53

Copy to:-

The Joint Director of Education

(Land & Estate)

Directorate of Education, Lucknow Road, Delhi -54

CONDITIONS:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Adarsh Gyan Sarover Balika Vidyalaya, Marginal Bandh, Main Road (5th Pusta), Ganwari, Delhi-53.
2. Building is comprised of : G+2
3. Type of Occupancy : Educational
4. Type of Case : Addition/Alternation
5. Details of Previous NOC : F6/DFS/MS/2010/2873 dated 04.10.2010 for (G+1)
6. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010
7. Date of Inspection : 17.05.2016
8. Name of the Inspecting Officers: : Suresh Singh, ADQ
9. Name of the designation of Officer from the building side : Vice Principal
10. Year of Construction : 1994
11. Applicant's letter No : AGSB/17/16 Dated 12.02.2016

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	15 m	MR
	Gate width	N.A	N.A	N.A
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	3 no.	3 no.	MR
	Basement	N.A	N.A	N.A
	B. Width of Staircases			
	Upper Floor	1.5 m	2 no. of 1.5 m 1 no. of 1.1 m	MR
	Basement	N.A	N.A	N.A
	c. Protection of exits	N.A	N.A	N.A
	Fire check door	N.A	N.A	N.A
	Pressurization	N.A	N.A	N.A
	e. No. of continuous staircases to terrace	2 no.	2 no.	MR
	g. Width of Corridor	1.5 m	1.5 m	MR
	h. Door Size	1 m	1 m	MR
3	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	Basement	N.A.	N.A	N.A
	Upper floor	N.A.	N.A	N.A

5.	Fire Extinguisher			
	Total numbers	06 no.	10 no.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	1 no.	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters	N.A	N.A	N.A.
8	MOEFA	N.A	Provided	MR
9	Public address System.	N.A	Provided	MR
10	Automatic Sprinkler System.			
	basement	N.A	N.A	N.A
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	N.A	N.A	N.A
	Number of hydrants per floor	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level	N.A	N.A	N.A
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main Pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby pump out put	N.A	N.A	N.A
	➤ Standby pump Head	N.A	N.A	N.A
	➤ Auto Starting /Manual stopping	N.A	N.A	N.A
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

N/11				
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	10,000 Liters	10,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The Delhi Fire Service has issued NOC vide letter no. F6/DFS/MS/2010/2873 dated 04.10.2010 for ground plus one upper floor, now the School is running at ground plus two upper floors.

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measure as required under rule 35 of the Delhi Fire Service rules 2010 is recommended to grant fire safety certificate.

Singh
25.5.16

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO (Shah)

Dy.CFO (Virendra Singh)

Submitted for approval please.

Dy CFO (NDR)

Singh
26/5/16