

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110 001


No. F.6/DFS/MS/GH/2016/ND2/904

Dated: 01/06/16

FIRE SAFETY CERTIFICATE

Certified that the **G.H Ridge Maidens**, located at **1004-05 Naiwalan , Faiz Road ,Karol Bagh, New Delhi-110005** is comprised of Basement, Ground floor , Mezzanine floor + Three Upper floors, basement is Vacant/ storage, Ground floor as reception , Mezzanine floor as office , first floor Having 05 Guest room, second floor having 06 Guest room and third floor having 05 guest rooms (**Total 16 guest rooms**), one staff room with staff kitchen on terrace was issued NOC by this department vide letter No.F.6/DFS/MS/GH/2013/541 dated 10-07-2013 for 16 guest rooms. The premises was re- inspected by the officer concerned of this department on 28-05-2016 in the presence of Sh. Parveen Kumar (Manager) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub-Division A-1 Guest House for 16 guest rooms** with effect from ~~01/06/2016~~ 01/06/2016 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....01/06/16.....at New Delhi by.



(Rajesh Panwar)

Dy. Chief Fire Officer
Delhi Fire Service
Ph -011-23412025

01/06/16

Copy to:-

1. The Addl. Commissioner of Police (Lic) 1st floor , P.S. , Defense Colony , New Delhi (Re. No. 1101/Joint C.P/Lic .(H) dated 16.05.2016)
2. Sh. Anoop Nayyar (Owner), G.H Ridge Maidens, 1004-05 Naiwalan Faiz Road ,Karol Bagh, New Delhi-110005

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : G.H Ridge Maidens, 1004-05 Naiwalan Faiz Road
Karol Bagh New Delhi-5
2. Type of Occupancy : Residential (G.H) B+ GF+ Mezz Floor + 03 upper floor,
total guest rooms-16
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/GH/2013/541 dated 10/07/2013
5. Fire Safety directives letter No : N/A
6. Date of inspection : 28/05/2016
7. Name of Inspecting Officer : Dy. C.F.O Rajesh Panwar
8. Name and designation of officer
From the building side : Sh. Parveen Kumar(Manager)
9. Year of Construction : Before 2001
10. Applicant's letter No. : 1101/Joint C.P/Lic .(H) Nil dated 16.05.2016


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible NA NA	09 mtr NA NA	MR NA NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	One Two	One Two	MR , Old Case MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	125 cms 125 cms	115 to 120 cms 160cm ,95 cms	MR, Old Case MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	One	One	MR
	e. Width of Corridor	1.0 Mtr	115, 110 cms	MR
	f. Door Size	1.0 Mtr.	80 cms X 205 cms	MR, Old Case
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA Sealed NA NA NA	NA MR NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH 12 ACPH	Exhaust Fans are Provided Natural Ventilation	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	03 at each floor ABC, Co2, WCO2 ISI marked	Provided Provided ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	MR MR MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/R NA NA	Provided NA NA	MR/ Area less than 200Sq/ mtr NA NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA NA NA NA NA NA NA NA NA NA 450 LPM 30 M Required NA	NA NA NA NA NA NA NA NA NA NA 450 LPM 30 M Provided NA	NA NA NA NA NA NA NA NA NA NA MR MR MR NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 5000 Ltr Required	NA NA NA NA 2500 Ltr Provided	NA NA NA NA MR, Old Case MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car 	NA NA Required	NA NA Provided	NA NA MR

	<ul style="list-style-type: none"> • Fireman's Grounding Switch • Lift Signage 	—	—	Old Lift
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/GH/2013/541 dated 10.07.2013 renewal under rule 35 of Delhi Fire Service Rules 2010, is recommended please.



Signature of Inspecting Officer


Name:- Rajesh Panwar

Designation:- Dy. C.F.O (NDZ)

Signature of Inspecting Officer


Name

Designation

~~Director~~  31/5

MC F.T letter is put up for signatures please,

Dy.CFO (Asst)



Red
1.6.10