

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No. **F6/DFS/MS/2016/908**

Dated: **01.06.2016**

**FIRE SAFETY CERTIFICATE**


Certified that M/S "RPM MAX" Restaurant (A Unit of What'Z Up) located at mezzanine and 1<sup>st</sup> floor, 40, Basant Lok, Vasant Vihar, New Delhi-67, comprised of basement, ground plus three upper floors but restaurant is at mezzanine and 1<sup>st</sup> floor only, owned/occupied by What'Z Up, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2013/760, dated 21-02-13. The premises was re-inspected by the officer concerned of this department on 28-05-2016 in the presence of Sh. Uday Pandey and found that the said eating house building (mezzanine and 1<sup>st</sup> floor only) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group-D Assembly Building(Eating House) with effect from **01.06.2016** for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....**01.06.2016** at New Delhi by

  
(Atul Garg)

Chief Fire Officer

T.No.011-26189168

Copy to:- 1. M/S "RPM MAX" Restaurant (A Unit of What'Z Up) mezzanine and 1<sup>st</sup> floor, 40, Basant Lok, Vasant Vihar, New Delhi. 

**Conditions for the validity of fire safety certificate are as under:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.



### INSPECTION REPORT

1. Name & address of the building : M/S "RPM MAX" Restaurant (A Unit of What'Z Up) located at mezzanine and 1<sup>st</sup> floor, 40, Basant Lok, Vasant Vihar, New Delhi-67.
2. Building is comprised of : Ground, mezzanine plus three upper floors. (Restaurant is at mezzanine and 1st floor only)
3. Type of Occupancy : Eating House (Assembly Building).
4. Type of Case : Renewal.
5. Details of Previous NOC : No.F.6/DFS/MS/EH/2013/760, dated-21.02.2013.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 28.05.2016.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of officer from the building side : Sh. Uday Pandey.
10. Year of Construction : Before 2002.
11. Applicant's letter No. : No. Nil, dated 23.05.16.

S.N	Minimum Standards on fire prevention and fire safety U/R33	Old NOC Requirements	Provided at Site	Remarks
1	Access to building			
	Road width	4.5 m	4.5m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	Required	Provided	MR
	Upper Floor	02Nos.	02Nos.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.25m & 1m	1.25m & 1m	MR(old case)
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace.	01No.	01No.	MR
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	02 nos.	1.1m & 1m	MR(old case)
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A	N.A
	Upper floor	12 a/c per hour	Exhaust fan Provided	MR
5.	Fire Extinguisher			
	Total numbers	04 nos.	04 nos.	MR
	Types	WCO <sub>2</sub> & ABC	WCO <sub>2</sub> , ABC & CO <sub>2</sub>	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01no.	1no. Provided	MR
	Length of hose reel hose	30 m	30m	MR
	Nozzle diameter	5mm	5mm	MR



7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement floor	N.A.	N.A.	N.A.
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	MR
	Number of hydrants in all floors	01No.	01No.	MR
	Hose Box	01No.	01No.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 lpm	450LPM	MR
	➤ Head of the Pump	30m	30m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	5000Ltrs.	5000Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	D.G. Set	MR
18	Refuge Area			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.


N-16

M/S "RPM MAX" Restaurant (A Unit of What'Z Up) mezzanine and 1<sup>st</sup> floor, 40, Basant Lok, Vasant Vihar.

19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/MS/DFS/2013/EH/760, dated 21.02.2013 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for kind consideration and necessary approval please.


  
20/5/16

Signature of the Inspecting Officer


Name Vedpal

Designation ADO

~~Dy.CFO D.P.B.~~

  
30/5/16

~~CFO. Atul Garg~~  
31/5/16

~~DIRECTOR OFS~~  
  
31/5