

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

No. F.6/DFS/MS/EH/2016/SZ/ 923

Dated: 03/06/16

FIRE SAFETY CERTIFICATE

Certified that the building of M/s Barbeque Nation (a unit of Barbeque nation Hospitality Ltd.), Unit No-206, 2nd Floor, Unity One, MLCP Plot, Janak Puri, West Metro Station, New Delhi-110058, is comprised of two basements, ground floor plus eight upper floors and terrace floor but restaurant is running at second floor only. The above restaurant owned /occupied by M/s Barbeque Nation (a unit of Barbeque nation Hospitality Ltd.). The Restaurant building was inspected by the officers concerned of this department on .05.2016 in the presence of Sh. Sheezad and found that the owner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant premises (**Restaurant Only**) is fit for occupancy class Group D Assembly building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....03/06/16..... at New Delhi.


(ATUL GARG)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

9/10

Copy to:-

1. The Deputy Health Officer,
South Delhi Municipal Corporation,
Public Health Department, West Zone,
Vishal Enclave, Rajouri Garden, N.D-27
(Ref. No. D-1442/40/WZ dated 02.05.2016)
2. The Manager
M/s Barbeque Nation (a unit of Barbeque nation Hospitality Ltd.),
Unit No-206, 2nd Floor, Unity One, MLCP Plot, Janak Puri,
West Metro Station, New Delhi-110058.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement shall be used strictly as per the provisions of the building bye laws.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Barbeque Nation, Unit No-206, 2nd Floor, Unity One, MLCP Plot, Janak Puri (W) Metro Station Complex, N.D-75.
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : Fresh
4. Details of Previous NOC : F.6/DFS/MS/2015/SZ/1900 dated 23.10.2015 for whole bldg.
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2014/207 dated 28.07.2014 for whole bldg.
6. Date of inspection : 14/05/2016
7. Name of Inspecting Officer : DY. CFO Atul Garg & D.O S.K. Tomar
8. Name and designation of officers
From the building side : Sh. Sheezad
9. Year of Construction : 2015
10. Applicant's letter No. : D-1442/40/WZ dt.02.05.16

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mtrs 06 mtrs 06 mtrs	14 mtrs 06 mtrs 06 mtrs	MR MR MR
2.	Number, Width, Type & Arrangement of Exits (Restaurant is at Second Floor only)			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Three Three	Three Three	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.5 mtrs 1.5 mtrs	1.5 mtrs 1.5 mtrs	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required Required	Provided Provided	MR MR
	d. No. of continuous staircases to terrace			
		One	Three	MR
	e. Width of Corridor	1.5 mtrs	1.5 mtrs	MR
	f. Door Size	02 mtrs	02 mtrs	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required Required NA NA Required	Provided Sealed NA Provided Provided	MR MR NA NA MR
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH 12 ACPH	Provided Natural Ventilation	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	05 Nos ABC, CO ₂ ISI marked	Provided Provided Provided	MR MR MR
6.	First-Aid Hose Reels (Common with parking cum commercial building)			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	MR MR MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power 	NA NA NA	Smoke & Heat Provided at GF Provided at GF Provided	NA NA NA NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	Provided near exit	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System (Restaurant is at second floor only)			
	<ul style="list-style-type: none"> • Basement 	NA	Provided	NA
	<ul style="list-style-type: none"> • Second Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	Provided	NA
11.	Internal Hydrants (common with parking cum commercial building)			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	150 MM	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	One	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	One	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	07 Provided	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	07 provided	NA
13.	Pumping Arrangements (common with parking cum commercial building)			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Water Curtain Pump ➤ Auto Starting/Manual Stopping ➤ Pump House Access 	NA	2850 LPM	NA
		NA	90 mtrs	NA
		NA	02 Nos	NA
		NA	280 LPM	NA
		NA	90 mtrs	NA
		NA	2850 LPM	NA
		NA	90 mtrs	NA
		NA	1000 LPM	NA
		NA	Provided	NA
		NA	Provided	NA
	<ul style="list-style-type: none"> • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	450 LPM	900 LPM	MR
		40 mtrs	40 mtrs	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting (common with parking cum commercial building)			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank 	NA	200000 Ltrs	NA
		NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
	<ul style="list-style-type: none"> • Overhead Tank capacity 	10000 Ltrs	20000 Ltrs	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	Required	Provided	MR
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	Required	Provided	MR
	<ul style="list-style-type: none"> • Communication In lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> • Lift Signage 	Required	Provided	MR

17.	Standby power supply	Required	02 D.G set of 500 KVA each.	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	Provided	NA
	• Flow Switch Panel	NA	Provided	NA
	• PA System Panel	NA	Provided	NA
	• Batter backup	NA	Provided	NA
	• Building Floor Plans	NA	Provided	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	Provided	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and fire safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note:- The restaurant is in the Multi Level Car Parking cum Commercial Area, Janak Puri West Metro Station, New Delhi and have common fire safety installations. The Multi Level Car Parking cum Commercial Area was issued Fire safety Certificate vide letter No. F.6/DFS/MS/2015/SZ/1900 dated 23.10.2015, placed at C-1.

Signature of Inspecting Officer

Name:- Atul Garg

Designation:- Dy. Chief Fire Officer

Signature of Inspecting Officer

Name:- S.K. Tomar

Designation:- Divisional Officer