

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No:

F6/DFS/MS/Hospital/2016/wr/937

Dated:

03/06/16

FIRE SAFETY CERTIFICATE

Certified that the **MGS Super Speciality Hospital**, located at **35/37, Rohtak Road, West Punjabi Bagh, New Delhi – 110026** comprised of Basement + Ground + 2 Upper Floors was issued FSC vide Letter no. F6/DFS/MS/2011/1993 dated 16-08-2011. The premises was re inspected by the officers concerned of this department on 20-05-2016 in the presence of Mr Naresh Babbar (Medical Director) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Institutional" Group C Sub Division C – 1 with effect from ....03/06/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....03/06/16... at New Delhi.

W 3/6  
(Vipin Kental)  
Chief Fire Officer,  
Ph: 011 – 23846352.

0/6 3/6

Copy to:-

1. The Medical Director,  
MGS Super Speciality Hospital, 35/37, Rohtak Road,  
West Punjabi Bagh, New Delhi – 110026.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building: **MGS Super Speciality Hospital, 35/37, Rohtak Road, West Punjabi Bagh, New Delhi – 110026.**
2. Type of Occupancy : Institutional (Hospital)
3. Type of Case : Renewal (Basement + Ground + 2 Upper Floors)
4. Details of previous NOC : Letter no. F6/DFS/MS/2011/1993 dated 16-08-2011
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/93/Hospital/2006 dated 09-12-1993
6. Date of inspection : 20-05-2016
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer  
from the building side : Dr. Naresh Babbar (Medical Director)
9. Year of Construction : 1991
10. Applicant's letter No. : Nil dated 04-04-2016

S No	Minimum standards on fire prevention and fire safety U/R33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	6 m	Provided except at one corner	MR (being old case)
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	4 Provided	MR
	• Basements	3	Provided	MR
	b. Width of staircases			
	• Upper floors	2 m	Provided 2x2mtr. 2x1.5mtr. each	MR (being old case)
	• Basements	2 m	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Found Provided	MR
	• Pressurization	Required	Found Provided	MR
	d. No of continuous staircase to terrace	2	Provided	MR
	e. Width Of Corridor	Old Case	1.5 mtr	MR (being old case)
	f. Door Size	Old Case	1.25 mtr	MR (being old case)
3.	Compartmentation			
	• Fire check door	Required	Found Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR



	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	Required	Found Provided	MR
		Required	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	15 nos.	Provided	MR
		ABC, WCO <sub>2</sub> , CO <sub>2</sub>	Provided	MR
		ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	02 on each floor	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	Smoke & Heat	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>• Size of riser/down- comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	100 mm	Provided	MR
		02	Provided	MR
		02	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	04	Provided	MR
		04	Provided	MR
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> </ul>			
		1620 LPM	Provided & functional	MR
		45mtrs	Provided	MR
		01	Provided	MR
		180 LPM	Provided	MR
		45mtr	Provided	MR
		1620lpm	Provided	MR
		45mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

	<ul style="list-style-type: none"> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	1,00,000 litre	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. Letter no. F6/DFS/MS/2011/1993 dated 16-08-2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name **MUKESH VERMA**

Designation **ADO (MM)**

Signature of the Inspecting Officer

Name

Designation

**DO (West)**

**27/5**

**1/1/2012**