

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**  
**Fax: 23412593, Email:gargatul@hotmail.com, Tel:- 011-26189168**



No.F6/MS/DFS/GH/2016/ 52/922

Dated: 03/06/16

**FIRE SAFETY CERTIFICATE**

Certified that the The JRD Guest House, located at B-7/113-A,Safdarjung Enclave, New Delhi-110029.comprised of basement, ground plus three upper floors (30 guest rooms) owned/occupied by A Unit of M/S JRD Buildcon Pvt Ltd.was granted FSC by this department vide letter No. F6/DFS/MS/GH/2013/452 dated :- 17/06/2013.The premises was re-inspected by the officer concerned of this department on 26/05/2016 in the presence of Mr. Ranjeev Duggal and observed that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group-A, Residential (Lodging or Rooming House)** with effect from...03/06/16...for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ...03/06/16...at New Delhi by.

  
(ATUL GARG)  
CHIEF FIRE OFFICER  
9c 

Copy to:-

Mr. Ranjeev Duggal  
The JRD Guest House,  
B-7/113-A, Safdarjung Enclave, New Delhi-110029  
Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building: - The JRD Guest House, B-7/113-A, Safdarjung Enclave, New Delhi-110029.
2. Type of occupancy:- Residential, Group-A, Rooming or Lodging Houses (Guest House)
3. Type of case: - Renewal
4. Details of previous NOC: - F6/DFS/MS/GH/2013/452 dated :- 17/06/2013
5. Fire safety directives No.- Nil
6. Date of inspection:- 27/05/2016
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mr. Duggal
9. Year of construction:- 2002
10. Applicant's letter No:- Nil dated 27/04/2016
11. Composition of building; - Basement & Ground Plus Three Upper Floor. (30 guest room)

(Old Case)

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	12mtr	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	02nos	Provided	MR
	2. Basements	02nos	Provided	MR
	B. Width of staircase			
	1. Upper floors	Required	1.10mtr & 1m	MR Old case
	2. Basements	Required	1.10mtr & 1m	MR Old Case
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01nos	01 nos.	MR
	E. Width of corridor	1.50m	Provided	MR
	F. Door size	1mtr	Provided	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	Exhaust Fan	MR
	2) Upper floors	12 a/c per hour	Exhaust Fan	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	12 Nos. Provided	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01 no.	Provided at each floor	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR

E

<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	Provided	.....
	2) Number of hydrants per floor	N/A	Provided	.....
	3) Hose box	N/A	Provided	.....
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	<b>1) Ground level</b>			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	<b>2) Terrace level</b>			
	a) Discharge of pump	450LPM	450LPM	MR
	b) Head of pump	35mtr	35 mtr	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Underground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000ltr	10,000 Ltrs.	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	N/A	N/A	N/A
<b>17.</b>	<b>Standby Power Supply</b>	Required	Provided DG Set	MR
<b>18.</b>	<b>Refuge Area</b>			
	Total area location	N/A	N/A	N/A



2/13

<b>19. Fire Control Room</b>	N/A	N/A	N/A
a) Detector system panel	N/A	N/A	N/A
b) Flow switch panel	N/A	N/A	N/A
c) PA system panel	N/A	N/A	N/A
d) Battery backup	N/A	N/A	N/A
e) Building floor plan	N/A	N/A	N/A
<b>20. Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire system provided in the building were checked and found functional at the time of inspection.

In view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No F6/DFS/MS/GH/2013/452 dated: - 17/06/2013, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended to grant fire safety certificate.

Accordingly DFA is put up for perusal and signature pl.

Signature of the inspecting officer

Name: - D.B.Mukherjee.

Designation:- Assistant Divisional Officer (BCP)

Dy CFO (D.P. Bhardwaj)

27/5/16