

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110 001

No. F.6/DFS/MS/GH/2016/ 952

Dated: 7/6/16

FIRE SAFETY CERTIFICATE

Certified that the **Golden Moments Party Palace** located at **870 East Park Road , Karol Bagh, New Delhi-110005** is comprised of Ground floor only ,having two party halls, office ,kitchen and store was granted NOC by this department vide letter No.F.6/DFS/MS/BNQT/2013/NDZ/999 dated 30-09-2013 . The premises was re- inspected by the officer concerned of this department on 01-06-2016 in the presence of Sh. Subodh Bawa and found that the said Banquet Hall building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **class D (a)(ii)"Assembly Building" (Ground Floor Only)** with effect from ~~7/6/16~~ 7/6/16---2016 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....7/6/16.....at New Delhi by.

(Rajesh Panwar)
Dy. Chief Fire Officer
Ph. 011-23412025

Copy to:-

1. Sh. Subodh Bawa , **Golden Moments Party Palace , 870 East Park Road , Karol Bagh, New Delhi-110005**

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : Golden Moments, Party Palace at 870, East Park Road
Karol Bagh , New Delhi -110005
2. Type of Occupancy : Assembly (Banquet Hall) Ground Floor only
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/BNQT/2013/NDZ/999 dated 30/09/2013
5. Fire Safety directives letter No : N/A
6. Date of inspection : 01/06/2016
7. Name of Inspecting Officer : Dy. C.F.O Rajesh Panwar
8. Name and designation of officers
From the building side : Sh. Subodh Bawa
9. Year of Construction : 2003
10. Applicant's letter No. : Nil dated 31.05.2016

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site (PSS Area)	Remarks MR/NMR (PSS Area)
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9 mtr 4.5 mtr NA	17 mtr 4.5 mtr NA	MR MR NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	NA NA	NA NA	NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2.0 Mtr.	2.4 mtr	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH 12 ACPH	NA Natural Ventilation	No Basement MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10 ABC, WCO2, CO2 ISI marked	Provided Provided ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Three 30 m 5 mm	Provided Provided Provided	MR(G. F. Only) MR MR


7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	NA NA	NA NA	NA NA
	<ul style="list-style-type: none"> Ground Floor Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm 01 01	150 mm Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA 900 lpm 30 mtr NA NA NA NA NA NA NA NA NA NA Required NA	NA 900 lpm 30 mtr NA NA NA NA NA NA NA NA NA NA Provided NA	NA MR, Old Case MR, Old Case NA NA NA NA NA NA NA NA MR NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA Required 15000 Ltr	NA NA NA Provided 15000 Ltr	NA NA NA MR MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA NA NA NA NA	NA NA NA NA NA	G.F. Only G.F. Only G.F. Only G.F. Only G.F. Only

17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NR	Provided	MR
20.	Special Fire Protection System for Protection of special Risks, if any:	Yes	ABC	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/BNQT/2013/NDZ/999 dated 30.09.2013 renewal under rule 35 of Delhi Fire Service Rules 2010, is recommended please.

Signature of Inspecting Officer




Name:- Rajesh Panwar

Designation:- Dy. C.F.O (NDZ)

Signature of Inspecting Officer

Name

Designation



6/6